

03-5-5829R

H NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15884

OPERATIONS PERMIT

Name: (owner) BETHUNE, DANIEL New Installation Septic Tank
 Property Location: SR# 2031 WIRE RD Repairs Nitrification Line
 Subdivision _____ Lot # _____
 TAX ID# _____ Quadrant # _____
 Contractor: LARRY SHARPE Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 2 of each ditch 100 ft. ditches 3 ft. ditches 18 in.
 French Drain: _____ Linear feet

PERMIT NO. 20074

Date: 5/8/03
 Inspected by: [Signature]
 Environmental Health Specialist

