

03-5-6561

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

No 15385

OPERATIONS PERMIT

Name: (owner) MOORE HOMES New Installation Septic Tank
 Property Location: SR# 2031 BYROS PONOS RD Repairs Nitrification Line
 Subdivision _____ Lot # 1A
 TAX ID# _____ Quadrant # _____
 Contractor: RAY MOORE Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18-22 in.

French Drain: _____ Linear feet

Date: 3/19/03

PERMIT NO. 19834

Inspected by: [Signature]
Environmental Health Specialist

