

00-011369

HARNETT COUNTY HEALTH DEPARTMENT

No 16600

IMPROVEMENT PERMIT

03-5-7982

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) John Burnette New Installation Septic Tank

Property Location: SR# 2026 / Hwy 217 Repairs Nitrification Line

Subdivision Byrd Mill Rd. Lot # — A1

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: Three Lot Size: 11.45 acrs (1 acre)

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 30-36 in.


French Drain Required: _____ Linear feet

Date: 16 May 2000
Signed: Vernon R. Dalg
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

⊕ Drawing not to scale
⊕ maintain setbacks
⊕ well setback is 50 feet

REVISED 10/15/03
ST



HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 16600. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent _____

Name: John Bannette Telephone # 497-4542

Address: 226 Bannette Lane Linden, NC

Property Location: SR # 2026 Road Name Byrd Mill

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision Byrd Mill Lot # A1

Number of Bedrooms Proposed: Three Lot size: _____

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well Public _____ Minimum Well Setback: 50 ft.

Type of System: Conventional Other _____

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 2 Length of lines 75 feet

Width of ditches 3 ft. Depth of ditches 30-36 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Vernon R. [Signature] Date: 16 May 2000