

PREPARED 4/18/08, 14:17:51
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 4/21/08

ADDRESS . . : 59802 *UNASSIGNED
CONTRACTOR : STATE MOBILE HOME MOVERS
OWNER . . . : OLD REPUBLIC NATIONAL TITLE #3
PARCEL . . . : 12-0576- - -0021- -03-
APPL NUMBER: 08-50019684 CP MANUFACTURED HOMES

SUBDIV:
PHONE : (910) 894-8038
PHONE :

DIRECTIONS : 401 S TO LEFT ON BYRD'S MILL RD APPROX
2.7 MILES ON LEFT LOT 3 JB

STRUCTURE: 000 000 28X76 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

	REQUESTED	INSP	DESCRIPTION	
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS	
T501 01	4/21/08	TI	R*MOBILE HOME FOUND./ M. WALL	TIME: 17:00 VRU #: 001596410

DP JH

----- COMMENTS AND NOTES -----

ADDRESS . . : 59802 *UNASSIGNED SUBDIV:
CONTRACTOR : STATE MOBILE HOME MOVERS PHONE : (910) 894-8038
OWNER . . . : OLD REPUBLIC NATIONAL TITLE #3 PHONE :
PARCEL . . . : 12-0576- - -0021- -03-
APPL NUMBER: 08-50019684 CP MANUFACTURED HOMES
DIRECTIONS : 401 S TO LEFT ON BYRD'S MILL RD APPROX
2.7 MILES ON LEFT LOT 3 JB

STRUCTURE: 000 000 28X76 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 02	4/21/08 4/21/08	OH DP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001596133 House is not ready for rough mobile home inspection everything under house needs to be done @ rough inspection, including drain line test.
T501 01	4/21/08 4/23/08	TI CA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001596410
T501 03	4/24/08	TI	R*MOBILE HOME FOUND./ M. WALL VRU #: 001598499

APJH

COMMENTS AND NOTES

ADDRESS : 2405 BYRDS MILL RD SUBDIV:
 CONTRACTOR : STATE MOBILE HOME MOVERS PHONE : (910) 894-8038
 OWNER : OLD REPUBLIC NATIONAL TITLE #3 PHONE :
 PARCEL : 12-0576- - -0021- -03-
 APPL NUMBER: 08-50019684 CP MANUFACTURED HOMES
 DIRECTIONS : 401 S TO LEFT ON BYRD'S MILL RD APPROX
 2.7 MILES ON LEFT LOT 3 JB

STRUCTURE: 000 000 28X76 4BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 02	4/21/08 4/21/08	JH DP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001596133 House is not ready for rough mobile home inspection everything under house needs to be done @ rough inspection, including drain line test.
T501 01	4/21/08 4/23/08	TI CA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001596410
T501 03	4/24/08 4/24/08	JH AP	R*MOBILE HOME FOUND./ M. WALL VRU #: 001598499
H824 01	4/24/08 4/24/08	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001599786
Z818 01	4/28/08 5/01/08	TI CA	PZ*ZONING INSPECTION VRU #: 001599836
A814 02	4/28/08 4/29/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001599828 ✓ 2405 BYRDS MILL RD LOT 3
Z818 02	5/07/08 5/06/08	TI CA	PZ*ZONING INSPECTION VRU #: 001605132
T503 01	5/08/08 5/07/08	TI CA	R*MOBILE HOME INSPECTION VRU #: 001605294
T503 02	5/09/08	TI	R*MOBILE HOME INSPECTION VRU #: 001605625
Z820 01	5/09/08 5/07/08	TI CA	PZ*ZONING/FINAL INSPECTION VRU #: 001605609

AP JH

COMMENTS AND NOTES

Unzoned

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD Mobile Home

Type of Construction: V

Owner of Building: Old Republic Antiques Tite

Building Address: 2405 Byrds Mill Rd

Zoning District: _____

Zoning Permit No.: _____

Conditional Use Permit No.: _____

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 5-9-08

Jana Hall
Building Official

Off-50019684

Zoning Official