

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: OAKWOOD HOMES
NEW REPAIR EXPANSION
Type of Structure: MAN. HOME (28'x76')
Proposed Wastewater System Type: CONVENTIONAL
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement Yes No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well 100 feet
Permit conditions: _____

PROPERTY LOCATION: BYEOS MILL RD
SUBDIVISION BYEOS MILL RD S/D LOT # 3
Site Improvements required prior to Construction Authorization Issuance: _____

Permit valid for: Five years
 No expiration

Authorized State Agent: [Signature] Date: 3/27/08 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: OAKWOOD HOMES
Facility Type: MAN. HOME (28'x76') New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** CONVENTIONAL (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable)
CONVENTIONAL (Repair)

PROPERTY LOCATION: BYEOS MILL RD
SUBDIVISION BYEOS MILL RD S/D LOT # 3

Installation Requirements/Conditions
Septic Tank Size 1000 gallons
Pump Tank Size _____ gallons
Number of trenches 2
Exact length of each trench 100 feet
Trenches shall be installed on contour at a Maximum Trench Depth of: 36 inches (Trench bottoms shall be level to +/-1/4" in all directions)
Pump Requirements: _____ ft. TDH vs. _____ GPM
Trench Spacing: 9 Feet on Center
Soil Cover: 24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Aggregate Depth: 6 inches below pipe, 2 inches above pipe, 12 inches total
Conditions: _____

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 3/27/08
Construction Authorization Expiration Date: 3/27/13

HTE# 09-5-19684

Permit # 24704

Harnett County Department of Public Health Site Sketch

ISSUED TO: Oakwood Homes PROPERTY LOCATOR: Byros Mill Rd
SUBDIVISION Byros Mill Rd S/D LOT # 3
Authorized State Agent: ~~[Signature]~~ ES (OLIVER TOLKSOORS) Date: 3/27/08

