

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 2/13/09

Proposed Facility: 4 Bedroom Home Design Flow (.1949): 420 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public [] Individual [] Well [] Spring [] Other


Evaluation Method: Auger Boring [] Pit [] Cut

Type of Wastewater: Sewage [] Industrial Process [] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR		
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz			
1	L5 10-13%	0-12"	G LS	VFA NS/HP					PS .4		
		12-34"	SBK SL	FL SS/SP							
		34" X	PM								
	2		0-24"	G LS	VFA NS/HP					PS .4	
			24-38"	SBK SL	FL SS/SP						
			38" X	SBK C	FI S/P						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% REC.	25% REC.
Site LTAR	.4	.4

5x60' @ 18"
 = REPAIR



Other Factors (.1946): _____

Site Classification (.1948): 85

Evaluated By: [Signature]

Others Present: