

-----

ADDRESS : 86713 \*UNASSIGNED SUBDIV:  
 CONTRACTOR : CHOO'S MOBILE HOME TRANSIT PHONE : (910) 850-6572  
 OWNER : MITCHELL LAVON JR & JANET M PHONE :  
 PARCEL : 12-0547- - -0026- -02-  
 APPL NUMBER: 09-50022100 CP MANUFACTURED HOMES  
 DIRECTIONS : BEHIND 1375 TEMPLE ROAD.  
 TAKE 210S, T/L ON TEMPLE ROAD. GO  
 APPROX 1MI, T/L AT 1375 TEMPLE. FOLLOW  
 DRIVEWAY TO PROPERTY APPROX 400YDS OFF  
 TEMPLE ROAD.  
 \*\*\*PWR CO: WAITING ON CUS\*\*\*  
 T/S: 05/14/2009 09:17 AM RDCONTE ---

-----

**STRUCTURE: 000 000 28X48 DWMH 3BDR**  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1995.00  
 PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW  
 WATER SUPPLY : NEW WELL

-----

**PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE**

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
T501 01	7/21/09 <i>7-21-09</i>	TI <i>DAJH</i>	R*MOBILE HOME FOUND./ M. WALL VRU #: 001797372

----- COMMENTS AND NOTES -----



7/21/2009 8:40:37 AM

Application number, type: 09 50022100 CP MANUFACTURED HOMES

Property address: 86713 UNASSIGNED

- 1) No water in drain line test.
- 2) Strap drain line every 4' per code.



OK Exit Cancel Copy Insert Delete Time stamp User defaults

-----  
ADDRESS . . : 86713 \*UNASSIGNED SUBDIV:  
CONTRACTOR : CHOO'S MOBILE HOME TRANSIT PHONE : (910) 850-6572  
OWNER . . . : MITCHELL LAVON JR & JANET M PHONE :  
PARCEL . . . : 12-0547- - -0026- -02-  
APPL NUMBER: 09-50022100 CP MANUFACTURED HOMES  
-----

DIRECTIONS : BEHIND 1375 TEMPLE ROAD.  
TAKE 210S, T/L ON TEMPLE ROAD. GO  
APPROX 1MI, T/L AT 1375 TEMPLE. FOLLOW  
DRIVEWAY TO PROPERTY APPROX 400YDS OFF  
TEMPLE ROAD.  
\*\*\*PWR CO: WAITING ON CUS\*\*\*  
T/S: 05/14/2009 09:17 AM RDCONTE ---  
-----

STRUCTURE: 000 000 28X48 DWMH 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 MOBILE HOME YEAR . . . . . : 1995.00  
PROPOSED USE . . . . . : DWMH SEPTIC - EXISTING? . . . . . : NEW  
WATER SUPPLY . . . . . : NEW WELL  
-----

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/21/09 7/21/09	JH DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001797372 1)No water in drain line test. 2)Strap drain line every 4' per code.
T501 02	7/23/09 <i>7-23-09</i>	TI <i>JH AP</i>	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001799212 T/S: 07/22/2009 03:17 PM JBROCK -----

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS . . : 86713 \*UNASSIGNED SUBDIV:  
CONTRACTOR : CHOO'S MOBILE HOME TRANSIT PHONE : (910) 850-6572  
OWNER . . : MITCHELL LAVON JR & JANET M PHONE :  
PARCEL . . : 12-0547- - -0026- -02-  
APPL NUMBER: 09-50022100 CP MANUFACTURED HOMES  
-----

DIRECTIONS : BEHIND 1375 TEMPLE ROAD.  
TAKE 210S, T/L ON TEMPLE ROAD. GO  
APPROX 1MI, T/L AT 1375 TEMPLE. FOLLOW  
DRIVEWAY TO PROPERTY APPROX 400YDS OFF  
TEMPLE ROAD.  
\*\*\*PWR CO: WAITING ON CUS\*\*\*  
T/S: 05/14/2009 09:17 AM RDCONTE ---  
-----

STRUCTURE: 000 000 28X48 DWMH 3BDR

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 MOBILE HOME YEAR . . . . . : 1995.00  
PROPOSED USE . . . . . : DWMH SEPTIC - EXISTING? . . . . . : NEW  
WATER SUPPLY . . . . . : NEW WELL  
-----

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/21/09 7/21/09	JH DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 001797372 1)No water in drain line test. 2)Strap drain line every 4' per code.
T501 02	7/23/09 7/23/09	JH AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 001799212 T/S: 07/22/2009 03:17 PM JBROCK ----- T/S: 07/23/2009 11:46 AM JBROCK -----
A814 01	7/24/09 7/29/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001799618 ✓1377 TEMPLE RD PER FB ----- BUNNLEVEL 28323 # BY DRIVE AND ON HOME T/S: 07/29/2009 01:05 PM TWARD -----
H824 01	8/24/09 8/24/09	OT AP	✓ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001812742 T/S: 08/24/2009 11:33 AM SSTEWARD ----- T/S: 08/24/2009 11:33 AM SSTEWARD -----
T507 01	8/27/09 8/27/09	JH CA	R*MANUFACTURED HOME FINAL VRU #: 001813898 per Lavon7/2009 10:36 AM JHALL -----
T507 02	9/15/09 <u>9-15-09</u>	TI <u>AL JV</u>	R*MANUFACTURED HOME FINAL VRU #: 001820992

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Owner: Levon Mitchell

911 Address: 1327 Temple Rd

State: N.C. Zip Code: \_\_\_\_\_

Date: 9-15-09

James H. Hall  
Building Official

PERMIT NUMBERS

Building Permit No.: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

Insulation Permit No.: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

MFG. Home: 09-50022100