Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 4-23-26 - 28-10
Proposed Facility: SW mft Design Flow (.1949): 360 Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☑ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	L	0-4	SL	fr GR NSNP					
4-5		4-20	SC-CLmy	Vfr GR / MASSIV / fr BLS P.	8"-20"				
					7.5YR 4/3				.2
6,7,8	L	0-24	SL	fr GR NSNP					
		24-36	SCLmy	Vfr m / fr BLS.P	30" 7.5YR 4/2				.35
9-10	L	0-36	SL	Vfr GR NSNP					
		36-48	SCL	Vfr m / fr BLS.P.	44				.6

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	1,2,3	9,10
Site LTAR	.35	.6

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: JL
Others Present: OT + SL