

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential
Name: McLamb Deborah H + Harvey T

Address: 178 Oaktree Ln
Dunn, NC 28334

Date: 8-2-16

Building Official: _____

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 16-50038610

[Handwritten Signature]

ADDRESS : 178 OAKTREE LN
CONTRACTOR : B J'S MOBILE HOME MOVERS
OWNER : MCLAMB DEBORAH H & HARVEY T
PARCEL : 06-0596- - -0135- - -
APPL NUMBER: 16-50038610 CP MANUFACTURED HOMES

SUBDIV: NANCY GODWIN ESTATE
PHONE : (910) 892-7972
PHONE :

DIRECTIONS : T/S: 05/02/2016 04:33 PM JFORBES ---
HAMILTON MHP LOT 178

STRUCTURE: 000 000 SWMH 14X70 3BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 MOBILE HOME YEAR : 1996.00
PROPOSED USE : SWMH SEPTIC - EXISTING? : EXISTING
WATER SUPPLY : COUNTY

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	7/11/16	DT	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002841203
	7/11/16	DA	T/S: 07/07/2016 02:57 PM JBROCK T/S: 07/11/2016 03:16 PM DETAYLOR Plumbing stand pipe must be filled up to floor level
A814 01	7/15/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002844546
	7/15/16	AP	178 OAKTREE LN DUNN 28334 T/S: 07/15/2016 12:13 PM SBENNETT
T501 02	7/15/16	DT	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002844538
	7/15/16	AP	T/S: 07/14/2016 01:34 PM JBROCK T/S: 07/15/2016 02:50 PM DETAYLOR
T507 01	7/29/16	DT	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002850535
	7/29/16	DA	T/S: 07/28/2016 01:33 PM LBENNETT T/S: 07/29/2016 02:10 PM DETAYLOR Install smoke detectors Unable to locate electrical panel Raise outside panel or remove vegetation Home appears to be occupied, should not be until after a C/O is issued
T507 02	8/02/16	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002851814
	8/2/16	AP	T/S: 08/01/2016 04:30 PM JFORBES

COMMENTS AND NOTES