



March 27, 2007

Shirley Valk
2645 Derby Rd.
Ellerbe, NC 28338-9505

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

Re: Harnett County Land Use Application HTE# 07-5-17119

Dear Ms. Valk,

The Harnett County Department of Public Health, Environmental Health Division on March 23, 2007, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a single-wide mobile home with 3 bedrooms, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.
- 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.
- 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

This lot (**Lot #1**), has been designated as the repair area for lot #2. Therefore, another home can not be placed on this lot.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R.S.
Joe West, R. S.

Environmental Health Specialist
Harnett County Department of Public Health

Cc: W & R Dev.
2516 Jefferson Davis Hwy.
Sanford, NC 27330