

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Myatt Nancy Rose Silvers

Address: 164 Myatt Ln
Angier NC 27501

Date: 6-12-17

Building Official:

[Signature]

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 1750041188

 ADDRESS : 164 MYATT LN SUBDIV:
 TENANT, NBR: **PREMISE 20188226**
 CONTRACTOR : A PLUS CONTRACTOR PHONE : (910) 690-9222
 OWNER : MYATT NANCY ROSE SILVERS #27 PHONE : (919) 639-2250
 PARCEL : 04-0682- - -0093- - -
 APPL NUMBER: 17-50041188 CP MOBILE HOME PARK
 DIRECTIONS : T/S: 04/19/2017 12:49 PM DJOHNSON --
 CROSSING MOBILE HOME PARK LOT 27
 164 MYATT LN
 **** PREMISE 20188226 ****

STRUCTURE: 000 000 14X66 3 BR NO DECKS OR PORCHES

BEDROOMS : 3.00 MOBILE HOME YEAR : 2017.00
 PROPOSED USE : SWMH SEPTIC - EXISTING? : ETANK

PERMIT: CPSW 00 CP MOBILE HOME SINGLEWIDE

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| A814 01 | 5/11/17 | SB | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002970952 |
| | 5/11/17 | AP | 164 MYATT LN ANGIER 27501 |
| | | | T/S: 05/11/2017 11:08 AM SBENNETT ----- |
| T501 01 | 5/11/17 | BS | R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002970754 |
| | 5/11/17 | DA | T/S: 05/10/2017 10:19 AM BPETRICH ----- |
| | | | T/S: May 11, 2017 11:57 AM BSUTTON ----- |
| | | | More than 1/4 of the piers exceed 30 inches in height, so an engineers design is required by state code, and the minute man system requires an engineered design for piers over 48 inches. 2. Longitudinal anchor exceeds 45 degrees. |
| T501 02 | 5/16/17 | BS | R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002973063 |
| | 5/16/17 | AP | T/S: 05/16/2017 08:30 AM LBENNETT ----- |
| | | | T/S: 05/16/2017 08:30 AM LBENNETT ----- |
| | | | ENGINEER LETTER IN FILE |
| Z818 01 | 5/30/17 | AD | PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002977668 |
| | 5/30/17 | CA | T/S: 05/26/2017 10:17 AM BPETRICH ----- |
| | | | T/S: 05/30/2017 09:06 AM DJOHNSON ----- |
| | | | CANCELLED BY CUSTOMER PER DONNA IN CP. T/S: 05/30/2017 08:43 AM ADRIGGER ----- |
| Z818 02 | 6/02/17 | AD | PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002979276 |
| | 6/02/17 | AP | T/S: 06/01/2017 08:12 AM BPETRICH ----- |
| | | | T/S: 06/02/2017 10:07 AM ADRIGGER ----- |
| T507 01 | 6/06/17 | DT | R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002980241 |
| | 6/06/17 | DA | T/S: 06/02/2017 03:57 PM LBENNETT ----- |
| | | | T/S: 06/06/2017 03:31 PM DETAYLOR ----- |
| | | | Right side door cannot open over steps, landing required |
| T507 02 | 6/12/17 | TI | R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002982783 |
| | <u>6/12/17</u> | <u>APDT</u> | T/S: 06/09/2017 08:47 AM LBENNETT ----- |

----- COMMENTS AND NOTES -----