

#02-5-4390

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Honeycutt Custom Homes

New Installation  Septic Tank

Property Location: SR# Hwy 55

Repairs  Nitrification Line

Subdivision Tuckerton Land Lot # 1

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 4 Lot Size: .175

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1200 gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface Drainage Field No. of ditches 4 exact length of each ditch 110 ft. width of ditches 3 ft. depth of ditches 18.22 in.

French Drain Required: - Linear feet

Date: 4-25-02

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manhart III Esq.  
Environmental Health Specialist



N.C. Hwy 55 E

HARNETT COUNTY HEALTH DEPARTMENT  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 19173. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Name Honeycreek Custom Homes Telephone # 919 291-2566

Address 5105 STELLBREEZE DRIVE F.N. N.C. 27526

Property Location SR#  Hwy 55  Road Name  Hwy 55

Subdivision Tonleywood Land Lot # 1 # Bedrooms Proposed 4 Lot size .75

TYPE OF SYSTEM

New Installation [ ] Repair [  ] Septic Tank [  ] Nitrification Lines

Conventional Other \_\_\_\_\_

[ ] Basement [ ] With Plumbing [ ] Without Plumbing

Water Supply: [ ] Well [  ] Public - Minimum Well Setback: 50' Ft.

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 4 Length of lines 110 Ft.

Width of ditches 3 ft. Depth of ditches 18-22 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Jane E. Marland  
Signature of Authorized Agent for Harnett County

4-25-02  
Date