


# SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940														
HORIZON 1 DEPTH		0-10"	0-29"												
TEXTURE GROUP	.1941(A)(1)	S	S												
CONSISTENCE	.1941	VFR	VFR												
STRUCTURE	.1941(A)(2)	G	G												
MINERALOGY	.1941(A)(3)	N3/ND	N3/ND												
HORIZON 2 DEPTH		10-30"	25" x												
TEXTURE GROUP	.1941(A)(1)	C	C												
CONSISTENCE	.1941	FR	FR												
STRUCTURE	.1941(A)(2)	SBK	SBK												
MINERALOGY	.1941(A)(3)	S3/SP	S3/SP												
HORIZON 3 DEPTH		30" x	2												
TEXTURE GROUP	.1941(A)(1)	PM													
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
HORIZON 4 DEPTH															
TEXTURE GROUP	.1941(A)(1)														
CONSISTENCE	.1941														
STRUCTURE	.1941(A)(2)														
MINERALOGY	.1941(A)(3)														
SOIL WETNESS	.1942														
RESTRICTIVE HORIZON	.1944														
SAPROLITE	.1943/1956														
CLASSIFICATION	.1948	PS	PS												
LONG TERM ACCEPTANCE RANGE	.1955	.35	.35												

ROAD



HOUSE NEEDS TO BE MOVED TO 25' OFF REAR PROP. LINE

4 x 75' OF 25% REDUCTION SYSTEM

7-28/

THE PLAN APPROVAL  
DISTRICT (1.19A) USE RAZOR Modular  
0752 BEDROOMS 4

11-10-02 David Johnson  
David Johnson  
6536

92

02

**Required Property Line Setback**

Minimum	Actual
35'	55'
10'	27'
25'	50'
10'	

DWAY

ROAD

McKAY DR SR 1122

SR 1122

CARNATION CIRCLE

CAMELLIA LANE (PRIVATE DRIVE)

CAMELLIA LANE (PRIVATE STREET)

AZALEA DRIVE (PRIVATE DRIVE)

91

01

ANDERSON CREEK COMMUNITY CHURCH

4405

1=200

