HTE # 04-5-10676R

RNETT COUNTY HEALTH DEP MENT
ENVIRONMENTAL HEALTH SEC ION

17566

OPERATIONS PERMIT

Name: (owner) Steve Lee / Ruth Grimm ☑ New Installation ☑ Septic Tank ☐ Repair

Property Location: SR# 1120 ☑ Nitrification Line ☐ Expansion
Subdivision Amber Lee Lot # ____ Tax ID # ____ Quadrant # ____

Contractor: Gary Carter Registration # ____

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☑ Public ☐ Community
Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☑ Other Pump to Quick 4 Chamber

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field	No. of ditches 4	exact length of each ditch 100 ft.	width of ditches 3 ft.	depth of ditches 18 in.

French Drain Required: ____ Linear feet Date: 7/1/2005

PERMIT NO. 19633 Inspected by: [signature] R.S.



* Repair for this property is located 1400 down our way N. East of lot