

HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

21654

HTE 0550011114

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) WINNIE, SCOTT & DENISE
Property Location: SR# 2026 BYROS MILL RD
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision COWAN SUBDIVISION Lot # 3

Tax ID # Quadrant #

Number of Bedrooms Proposed: 4 Lot Size: 2.0ac

Basement with Plumbing: Garage:

Water Supply: Well, Public, Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other

Size of tank: Septic Tank: Existing gallons Pump Tank: gallons

Subsurface Drainage Field: No. of ditches, exact length of each ditch, width of ditches, depth of ditches


French Drain Required: Linear feet

Date: 1/27/05

Signed: [Signature] Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

\* MAINTAIN ALL SETBACKS
\* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 21654. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. ***This authorization will be invalid if ownership, site plans, or intended use change.***

WINNIE, SCOTT & DENISE 910-658-6158  
Name Telephone #

2380 BYROS MILL RD ERWIN NC 28334  
Address

2026 BYROS MILL RD  
Property Location SR# Road Name

COWAN SD 3 4 2.0ac  
Subdivision Lot # # Bedrooms Proposed Lot Size

**TYPE OF SYSTEM**

New Installation  Repair  Septic Tank  Nitrification Lines

Conventional  Other \_\_\_\_\_

Basement  With Plumbing  Without Plumbing

Water Supply:  Well  Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank EXISTING gal Pump Chamber \_\_\_\_\_ gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 2 Length of lines 50 Ft.

Width of ditches 3 ft. Depth of ditches 30 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] RS 1/24/05  
Signature of Authorized Agent for Harnett County Date