

HARNETT COUNTY HEALTH DEPARTMENT

HTE 05-50012719

IMPROVEMENT PERMIT

22095

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) MICHAEL HENRY
Property Location: SR# HWY 210
New Installation [X] Septic Tank [X]
Repairs [] Nitrification Line [X]

Subdivision VANDERGRIFT FARM Lot # 23

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 4 (480 sqd) Lot Size: 16.25 ac

Basement with Plumbing: [] Garage: []

Water Supply: [X] Well [] Public [] Community []

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [] Conventional [X] Other 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain Required: _____ Linear feet

Date: 8/25/05
Signed: [Signature] ES (OLIVER TOLKSDORF)
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

* MEET ON SITE FOR FINAL LAYOUT



HWY 210

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22095. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

MICHAEL HENRY 540-937-5005
Name Telephone #

5229 JEFFERSON RD JEFFERSON VA 22724
Address

Hwy 210
Property Location SR# Road Name

VANDERGRIF Fm 23 4 (480 sq ft) 16,25 AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

- New Installation [] Repair Septic Tank Nitrification Lines
[] Conventional Other 25% REDUCTION SYSTEM
[] Basement [] With Plumbing [] Without Plumbing

Water Supply: Well [] Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 4 Length of lines 75 Ft.

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature]
Signature of Authorized Agent for Harnett County

8/25/05
Date