

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : PHONE :
OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 <u>1-20-10</u>	TI <i>CA JH</i>	R*BLDG SLAB INSP VRU #: 001872913 <i>font need</i>
B101 02	1/20/10 <u>1-20-10</u>	TI <i>DA JH</i>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434

Need Engineer letter for tying in existing footing

----- COMMENTS AND NOTES -----

ADDRESS . . : 12 JAYLIN BLVD
CONTRACTOR :
OWNER . . . : TOP HAT RENTALS
PARCEL . . . : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE :
PHONE : (910) 273-4110

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00
SEPTIC - EXISTING? : EXISTING
WATER SUPPLY : COUNTY

PROPOSED USE : MOD & ADDITION
SEWER : UNKNOWN

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

E207 01 1/21/10 TI R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001873751
1-21-10 AP JH T/S: 01/20/2010 11:38 AM RDCONTE -----
TEMP POWER POLE

COMMENTS AND NOTES

ADDRESS . . : 12 JAYLIN BLVD
 CONTRACTOR :
 OWNER . . : TOP HAT RENTALS
 PARCEL . . : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME
 DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
 RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
 CHURCH RD PROPERTY WILL BE ON LEFT.
 LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
 OF CREEKSVILLE CHURCH RD AND JAYLIN
 BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
 -A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : EXISTING
 WATER SUPPLY : COUNTY
 PROPOSED USE : MOD & ADDITION
 SEWER : UNKNOWN

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 -----
B101 03	3/09/10 3-9-10	TI AP JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 <i>Per Engineer letter</i>

COMMENTS AND NOTES

WILBUR E. DEES, P.E., P.L.S.
CONSULTING ENGINEERING AND LAND SURVEYING
2927 MIDDLESEX ROAD
FAYETTEVILLE, N. C., 28306
PHONE\FAX (910) 425-1941
CELL (910) 624-4779

MARCH 5, 2010

HARNETT COUNTY
BUILDING INSPECTIONS DEPARTMENT
P.O. BOX 65
LILLINGTON, NORTH CAROLINA 27546

TO WHOM IT MAY CONCERN:

RE: GARAGE EXTENSION
12 JAYLIN OAKS BOULEVARD
SPRING LAKE, NORTH CAROLINA


DEAR SIR:

THE ABOVE REFERENCED GARAGE EXTENSION IS BEING CONSTRUCTED UNDER BUILDING PERMIT NO. 05-50013109, DATED JANUARY 7, 2010. THE NEW GARAGE WILL ATTACH TO THE EXISTING CONCRETE FOOTING AT FOUR DIFFERENT LOCATIONS. TO TIE TOGETHER THE EXISTING CONCRETE FOOTING AND THE NEW FOOTINGS, I RECOMMEND DRILLING THE EXISTING CONCRETE FOOTINGS, WHERE THE NEW FOOTINGS ABUT, AND PLACING TWO #5 DOWELS 8 INCHES DEEP INTO THE EXISTING CONCRETE FOOTINGS AND EXTENDING THEM A MINIMUM OF 18 INCHES INTO THE NEW CONCRETE FOOTINGS. THE NEW DOWELS ARE TO BE EPOXYED INTO THE EXISTING CONCRETE FOOTINGS AT EACH LOCATION. USE "RED HEAD" EPCON G-5 HIGH STRENGTH EPOXY. DRILL THE NEW DOWEL HOLES 4 INCHES BELOW THE TOP OF THE FOOTINGS AND 6 INCHES CENTER TO CENTER.

SHOULD YOU HAVE ANY QUESTIONS, PLEASE DO NOT HESITATE TO CONTACT ME.

SINCERELY,


WILBUR E. DEES, P.E., P.L.S.



ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : PHONE :
 OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
 RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
 CHURCH RD PROPERTY WILL BE ON LEFT.
 LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
 OF CREEKSVILLE CHURCH RD AND JAYLIN
 BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
 -A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
 SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
 WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 <u>3-25-10</u>	TI <i>DA JH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262

COMMENTS AND NOTES

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : PHONE :
OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 <i>4-1-10</i>	TI <i>Op JH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 <i>Previous violations was not corrected</i>

COMMENTS AND NOTES

ADDRESS . . : 12 JAYLIN BLVD
CONTRACTOR :
OWNER . . . : TOP HAT RENTALS
PARCEL . . . : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE :
PHONE : (910) 273-4110

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON -----

4-7-10 AP JH

----- COMMENTS AND NOTES -----

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : PHONE :
OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L -----

CONTINUED ONTO NEXT PAGE

ADDRESS . . : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : PHONE :
OWNER . . : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL . . : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	<u>4/08/10</u> <u>4-8-10</u>	TI <u>APJH</u>	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE ----- PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE.

----- COMMENTS AND NOTES -----

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : PHONE :
 OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
 RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
 CHURCH RD PROPERTY WILL BE ON LEFT.
 LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
 OF CREEKSVILLE CHURCH RD AND JAYLIN
 BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
 -A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
 SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
 WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L -----

CONTINUED ONTO NEXT PAGE

ADDRESS : 12 JAYLIN BLVD
CONTRACTOR :
OWNER : TOP HAT RENTALS
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE :
PHONE : (910) 273-4110

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	4/08/10 4/08/10	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE.
R125 01	4/16/10 <u>4-16-10</u>	TI <u>AP JH</u>	ONE TRADE ROUGH IN VRU #: 001910551 <i>Finish open floor for spiral stairs</i>

COMMENTS AND NOTES

ADDRESS . . : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : PHONE :
OWNER . . . : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL . . . : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	4/08/10 4/08/10	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE ----- PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE. -----
R125 01	4/16/10 4/16/10	JH AP	ONE TRADE ROUGH IN VRU #: 001910551 Finish open floor inspection @ spiral stairs-----
B103 06	5/14/10 5/14/10	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001926134 T/S: 05/14/2010 07:28 AM NTART -----
B101 04	5/14/10	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001926781 T/S: 05/14/2010 07:29 AM NTART ----- -----
----- COMMENTS AND NOTES -----			

S-14-10 APJH

Back porch

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : PHONE :
 OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
 RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
 CHURCH RD PROPERTY WILL BE ON LEFT.
 LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
 OF CREEKSVILLE CHURCH RD AND JAYLIN
 BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
 -A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
 SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
 WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L -----

CONTINUED ONTO NEXT PAGE

ADDRESS : 12 JAYLIN BLVD
 CONTRACTOR :
 OWNER : TOP HAT RENTALS
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
 PHONE :
 PHONE : (910) 273-4110

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
 RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
 CHURCH RD PROPERTY WILL BE ON LEFT.
 LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
 OF CREEKSVILLE CHURCH RD AND JAYLIN
 BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
 -A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
 SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
 WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tieing into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L -----

CONTINUED ONTO NEXT PAGE

 ADDRESS : 12 JAYLIN BLVD
 CONTRACTOR :
 OWNER : TOP HAT RENTALS
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME
 SUBDIV: JAYLIN OAKS
 PHONE :
 PHONE : (910) 273-4110

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	4/08/10 4/08/10	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE.
R125 01	4/16/10 4/16/10	JH AP	ONE TRADE ROUGH IN VRU #: 001910551 Finish open floor inspection @ spiral stairs
B103 06	5/14/10 5/14/10	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001926134 T/S: 05/14/2010 07:28 AM NTART
B101 04	5/14/10 5/14/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001926781 T/S: 05/14/2010 07:29 AM NTART
R125 02	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943419 T/S: 06/18/2010 02:10 PM NTART
R425 01	6/21/10 <u>6/21/10</u>	TI <u>DA DT</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001943604 T/S: 06/18/2010 02:11 PM NTART

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312149
A814 01	12/01/06 12/01/06	TI AP	ADDRESS CONFIRMATION VRU #: 001316371 12 JAYLIN BLVD LOT 1
B103 01	12/01/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001316389
B103 02	12/04/06 12/04/06	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317577
B119 01	12/12/06 12/12/06	CE AP	R*MOD MARRIAGE WALL VRU #: 001321405 POST PERMIT ON SITE
H824 01	11/24/09 11/24/09	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001856657 T/S: 12/01/2009 12:02 PM SSTEWARD T/S: 12/01/2009 12:03 PM SSTEWARD
B117 01	6/21/10 <u>6/21/10</u>	TI <u>DA DT</u>	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001943596 T/S: 06/18/2010 02:11 PM NTART

*The house will
 internal trades &
 building.*

----- COMMENTS AND NOTES -----

ADDRESS : 12 JAYLIN BLVD
CONTRACTOR :
OWNER : TOP HAT RENTALS
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE :
PHONE : (910) 273-4110

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tying into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tying into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L -----

CONTINUED ONTO NEXT PAGE

ADDRESS : 12 JAYLIN BLVD
CONTRACTOR :
OWNER : TOP HAT RENTALS
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE :
PHONE : (910) 273-4110

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	4/08/10 4/08/10	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE.
R125 01	4/16/10 4/16/10	JH AP	ONE TRADE ROUGH IN VRU #: 001910551 Finish open floor inspection @ spiral stairs
B103 06	5/14/10 5/14/10	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001926134 T/S: 05/14/2010 07:28 AM NTART
B101 04	5/14/10 5/14/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001926781 T/S: 05/14/2010 07:29 AM NTART
R125 02	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943419 T/S: 06/18/2010 02:10 PM NTART
R425 01	6/21/10 6/21/10	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001943604 T/S: 06/18/2010 02:11 PM NTART 1. Truss straps not all nailed to trusses. 2. Fire block drop ceiling in garage. 3. Fire block gable end of upstairs bedroom. 4. Need web bracing in accordance with documents. T/S: 06/21/2010 02:39 PM DETAYLOR
R125 03	6/23/10 6/23/10	TI AP DT	ONE TRADE ROUGH IN VRU #: 001944953

COMMENTS AND NOTES

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : MILES LEE HARRIS PLUMBING PHONE : (910) 424-0574
OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tying into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tying into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L -----

CONTINUED ONTO NEXT PAGE

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : MILES LEE HARRIS PLUMBING PHONE : (910) 424-0574
 OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	4/08/10 4/08/10	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE ----- PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE.
R125 01	4/16/10 4/16/10	JH AP	ONE TRADE ROUGH IN VRU #: 001910551 Finish open floor inspection @ spiral stairs-----
B103 06	5/14/10 5/14/10	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001926134 T/S: 05/14/2010 07:28 AM NTART -----
B101 04	5/14/10 5/14/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001926781 T/S: 05/14/2010 07:29 AM NTART -----
R125 02	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943419 T/S: 06/18/2010 02:10 PM NTART -----
R425 01	6/21/10 6/21/10	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001943604 T/S: 06/18/2010 02:11 PM NTART ----- 1. Truss straps not all nailed to trusses. 2. Fire block drop ceiling in garage. 3. Fire block gable end of upstairs bedroom. 4. Need web bracing in accordance with documents. T/S: 06/21/2010 02:39 PM DETAYLOR -----
R125 03	6/23/10 6/24/10	DT AP	ONE TRADE ROUGH IN VRU #: 001944953
R131 01	3/23/11 <u>3-23-11</u>	TI <i>OP JH</i>	ONE TRADE FINAL TIME: 17:00 VRU #: 002056950 T/S: 03/21/2011 11:20 AM RDCONTE ----- ***PLEASE CALL 30MIN PRIOR TO INSPECTION 910-273-4110 OR 910-273-4586***

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/21/10 1/21/10	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001873751 T/S: 01/20/2010 11:38 AM RDCONTE ----- TEMP POWER POLE
R125 01	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943428 T/S: 06/18/2010 02:10 PM NTART -----
R131 01	3/23/11 <u>3-23-11</u>	TI <i>OP JH</i>	ONE TRADE FINAL TIME: 17:00 VRU #: 002056968 T/S: 03/21/2011 11:24 AM RDCONTE -----

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312149

CONTINUED ONTO NEXT PAGE

ADDRESS : 12 JAYLIN BLVD
CONTRACTOR : MILES LEE HARRIS PLUMBING
OWNER : TOP HAT RENTALS
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE : (910) 424-0574
PHONE : (910) 273-4110

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	12/01/06	TI	ADDRESS CONFIRMATION VRU #: 001316371
	12/01/06	AP	12 JAYLIN BLVD LOT 1
B103 01	12/01/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001316389
	12/01/06	CA	
B103 02	12/04/06	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317577
	12/04/06	AP	
B119 01	12/12/06	CE	R*MOD MARRIAGE WALL VRU #: 001321405
	12/12/06	AP	POST PERMIT ON SITE
H824 01	11/24/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001856657
	11/24/09	AP	T/S: 12/01/2009 12:02 PM SSTEWARD ----- T/S: 12/01/2009 12:03 PM SSTEWARD -----
B117 01	6/21/10	DT	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001943596
	6/21/10	AP	T/S: 06/18/2010 02:11 PM NTART -----
R131 01	3/23/11	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 002056984
	<u>3-23-11</u>	<u>DA JV</u>	T/S: 03/21/2011 11:25 AM RDCONTE -----

PERMIT: CPMR 00 CP MECHANICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	6/21/10	TI	ONE TRADE ROUGH IN VRU #: 001943446
	6/18/10	CA	T/S: 06/18/2010 02:10 PM NTART -----
R131 01	3/23/11	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 002056976
	<u>3-23-11</u>	<u>DA JV</u>	T/S: 03/21/2011 11:25 AM RDCONTE -----

PERMIT: CPPR 00 CP PLUMBING RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	6/21/10	TI	ONE TRADE ROUGH IN VRU #: 001943455
	6/18/10	CA	T/S: 06/18/2010 02:11 PM NTART -----
R131 01	3/23/11	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 002056992
	<u>3-23-11</u>	<u>DA JV</u>	T/S: 03/21/2011 11:25 AM RDCONTE -----

COMMENTS AND NOTES

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
CONTRACTOR : MILES LEE HARRIS PLUMBING PHONE : (910) 424-0574
OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

DIRECTIONS : JAYLIN OAKS SUB PHASE 1. TAKE 210S
RIGHT ON RAY RD LEFT ONTO CREEKSVILLE
CHURCH RD PROPERTY WILL BE ON LEFT.
LEFT ONTO JAYLIN BLVD LOT IS ON CORNER
OF CREEKSVILLE CHURCH RD AND JAYLIN
BLVD DRIVEWAY IS OFF OF JAYLIN BLVD.
-A.DRIGGERS

STRUCTURE: 000 000 43X79.6 MOD / 54X24 ADD 4BD/4BA TOTAL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : MOD & ADDITION
SEPTIC - EXISTING? : EXISTING SEWER : UNKNOWN
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312156
B103 01	12/04/06 12/01/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317569
B103 02	12/29/06 12/29/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001329580 PORCH FOUND. ONLY
B111 01	1/20/10 1/20/10	JH CA	R*BLDG SLAB INSP VRU #: 001872913 did not needr letter for tying into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 01:23 PM JHALL -----
B101 02	1/20/10 1/20/10	JH DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001873009 T/S: 01/19/2010 12:05 PM RDCONTE ----- PARTIAL INSPECTIONS WERE DONE ON THIS HOUSE IN 06. THE NEW OWNER BOUGHT HOME AS A FORCLOSED HOME AND HAS UPDATED AND EXPANDED THE PLANS. ANY QUESTIONS PLEASE CALL ME AT EXT 6434 Need engineer letter for tying into existing footing & left part of existing garage wall footing appears to be only 5" it should be 8" min per code.- T/S: 01/20/2010 ----- ---
B101 03	3/09/10 3/09/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892376 per engineer letter -----
B103 03	3/25/10 3/25/10	JH DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001899262 Need to remove dirt down to footing inside & outside of foundation wall for projection inspection
B103 04	4/01/10 4/01/10	JH DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001903006 Previous violations not corrected -----
B103 05	4/07/10 4/07/10	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001906288 T/S: 04/07/2010 10:26 AM DJOHNSON ----- L

CONTINUED ONTO NEXT PAGE

*See page 4
for Mod.
final*

 ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : MILES LEE HARRIS PLUMBING PHONE : (910) 424-0574
 OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 01	4/08/10 4/08/10	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001906304 T/S: 04/07/2010 10:55 AM RDCONTE ----- PARTIAL OPEN FLOOR. CURVED STAIR AREA TO BE INSPECTED AT A LATER DATE.
R125 01	4/16/10 4/16/10	JH AP	ONE TRADE ROUGH IN VRU #: 001910551 Finish open floor inspection @ spiral stairs-----
B103 06	5/14/10 5/14/10	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001926134 T/S: 05/14/2010 07:28 AM NTART -----
B101 04	5/14/10 5/14/10	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001926781 T/S: 05/14/2010 07:29 AM NTART -----
R125 02	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943419 T/S: 06/18/2010 02:10 PM NTART -----
R425 01	6/21/10 6/21/10	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001943604 T/S: 06/18/2010 02:11 PM NTART ----- 1. Truss straps not all nailed to trusses. 2. Fire block drop ceiling in garage. 3. Fire block gable end of upstairs bedroom. 4. Need web bracing in accordance with documents. T/S: 06/21/2010 02:39 PM DETAYLOR -----
R125 03	6/23/10 6/24/10	DT AP	ONE TRADE ROUGH IN VRU #: 001944953
R131 01	3/23/11 3/23/11	JH DA	ONE TRADE FINAL TIME: 17:00 VRU #: 002056950 T/S: 03/21/2011 11:20 AM RDCONTE ----- ***PLEASE CALL 30MIN PRIOR TO INSPECTION 910-273-4110 OR 910-273-4586*** 1)House numbers. 2)Labels for garage doors windload. 3)Missing light in upstairs bedroom (green). 4)Label panel in house. 5)Need vent wells on vent on front of house. 6)2 ground rods @ service no closer than 6'. 7)Need grounding bar @ meter for cable & phone. 8)Label AC units @ end of house. 9)Need receptacle on back porch. 10)Need permit for pool in back yard. 11)Insulation under house down throughout house. 12)Need 100 percent cover of 6 mill poly fastened in place. 13)
R131 02	3/25/11 3/24/11	TI CA	ONE TRADE FINAL TIME: 17:00 VRU #: 002059095 T/S: 03/24/2011 03:02 PM NTART ----- T/S: 03/24/2011 04:51 PM NTART -----
R131 03	3/29/11 <u>3/29/11</u>	TI <u>AP DT</u>	ONE TRADE FINAL TIME: 17:00 VRU #: 002059640 T/S: 03/28/2011 08:48 AM VBROWN -----

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	1/21/10	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001873751

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS : 12 JAYLIN BLVD SUBDIV: JAYLIN OAKS
 CONTRACTOR : MILES LEE HARRIS PLUMBING PHONE : (910) 424-0574
 OWNER : TOP HAT RENTALS PHONE : (910) 273-4110
 PARCEL : 01-0513- - -0217- -01-
 APPL NUMBER: 05-50013109 CP MODULAR HOME

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	1/21/10	AP	T/S: 01/20/2010 11:38 AM RDCONTE TEMP POWER POLE
R125 01	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943428 T/S: 06/18/2010 02:10 PM NTART
R131 01	3/23/11 3/23/11	JH DA	ONE TRADE FINAL TIME: 17:00 VRU #: 002056968 T/S: 03/21/2011 11:24 AM RDCONTE 1)House numbers. 2)Labels for garage doors windload. 3)Missing light in upstairs bedroom (green). 4)Label panel in house. 5)Need vent wells on vent on front of house. 6)2 ground rods @ service no closer than 6'. 7)Need grounding bar @ meter for cable & phone. 8)Label AC units @ end of house. 9)Need receptacle on back porch. 10)Need permit for pool in back yard. 11)Insulation under house down throughout house. 12)Need 100 percent cover of 6 mill poly fastened in place. 13)
R131 02	3/25/11 3/24/11	TI CA	ONE TRADE FINAL TIME: 17:00 VRU #: 002059103 T/S: 03/24/2011 03:02 PM NTART T/S: 03/24/2011 04:52 PM NTART
R131 03	3/29/11 <u>3/29/11</u>	TI <u>AP DT</u>	ONE TRADE FINAL TIME: 17:00 VRU #: 002060002 T/S: 03/28/2011 02:07 PM NTART

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/22/06 11/22/06	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001312149
A814 01	12/01/06 12/01/06	TI AP	ADDRESS CONFIRMATION VRU #: 001316371 ✓12 JAYLIN BLVD LOT 1
B103 01	12/01/06 12/01/06	TI CA	✓R*BLDG FOUND & TEMP SVC POLE VRU #: 001316389
B103 02	12/04/06 12/04/06	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001317577
B119 01	12/12/06 12/12/06	CE AP	R*MOD MARRIAGE WALL VRU #: 001321405 POST PERMIT ON SITE
H824 01	11/24/09 11/24/09	OT AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001856657 T/S: 12/01/2009 12:02 PM S STEWART T/S: 12/01/2009 12:03 PM S STEWART
B117 01	6/21/10 6/21/10	DT AP	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 001943596 T/S: 06/18/2010 02:11 PM NTART
R131 01	3/23/11 3/23/11	JH DA	ONE TRADE FINAL TIME: 17:00 VRU #: 002056984 T/S: 03/21/2011 11:25 AM RDCONTE 1)House numbers. 2)Labels for garage doors windload. 3)Missing light in upstairs bedroom (green). 4)Label panel in house. 5)Need vent wells on vent on front of house. 6)2 ground rods @ service no closer than 6'. 7)Need grounding

CONTINUED ONTO NEXT PAGE

ADDRESS : 12 JAYLIN BLVD
CONTRACTOR : MILES LEE HARRIS PLUMBING
OWNER : TOP HAT RENTALS
PARCEL : 01-0513- - -0217- -01-
APPL NUMBER: 05-50013109 CP MODULAR HOME

SUBDIV: JAYLIN OAKS
PHONE : (910) 424-0574
PHONE : (910) 273-4110

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			bar @ meter for cable & phone. 8)Label AC units @ end of house. 9)Need receptacle on back porch. 10)Need permit for pool in back yard. 11)Insulation under house down throughout house. 12)Need 100 percent cover of 6 mill poly fastened in place. 13)
R131 02	3/25/11 3/24/11	TI CA	ONE TRADE FINAL TIME: 17:00 VRU #: 002059087 T/S: 03/24/2011 03:01 PM NTART ----- T/S: 03/24/2011 04:52 PM NTART -----
R429 01	3/29/11 <u>3/29/11</u>	TI <u>AP DT</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002059996 T/S: 03/28/2011 02:06 PM NTART ----- <i>FCR Modular</i>

PERMIT: CPMR 00 CP MECHANICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943446 T/S: 06/18/2010 02:10 PM NTART -----
R131 01	3/23/11 3/23/11	JH DP	ONE TRADE FINAL TIME: 17:00 VRU #: 002056976 T/S: 03/21/2011 11:25 AM RDCONTE ----- T/S: 03/23/2011 12:17 PM JHALL -----
R131 02	3/29/11 <u>3/29/11</u>	TI <u>AP DT</u>	ONE TRADE FINAL TIME: 17:00 VRU #: 002060010 T/S: 03/28/2011 02:08 PM NTART -----

PERMIT: CPPR 00 CP PLUMBING RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	6/21/10 6/18/10	TI CA	ONE TRADE ROUGH IN VRU #: 001943455 T/S: 06/18/2010 02:11 PM NTART -----
R131 01	3/23/11 3/23/11	JH DP	ONE TRADE FINAL TIME: 17:00 VRU #: 002056992 T/S: 03/21/2011 11:25 AM RDCONTE ----- T/S: 03/23/2011 12:17 PM JHALL ----- T/S: 03/24/2011 03:03 PM NTART ----- T/S: 03/24/2011 04:37 PM NTART ----- T/S: 03/24/2011 04:38 PM NTART -----
R131 02	3/29/11 <u>3/29/11</u>	TI <u>AP DT</u>	ONE TRADE FINAL TIME: 17:00 VRU #: 002060028 T/S: 03/28/2011 02:08 PM NTART -----

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential
Name: Top Gun Rentals & Properties

Address: 12 Jaylin Blvd
Spring Lake, NC

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 00
MFG Home: _____

Date: 3/24/11

Building Official: _____