

HTE# 05-50013273RR

# IMPROVEMENT PERMIT 22461

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) SHERNITA KELLY New Installation  Septic Tank  Repair

Property Location: SR# 1244 MOORES CHAPEL RD Nitrification Line  Expansion

Subdivision SPRING HILL S/D Lot # 2

Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 4 (480 gpd) Lot Size: .942 AC

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

**Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.**

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 460 width of ditches 3 depth of ditches 18-20 in.

French Drain Required: \_\_\_\_\_ Linear feet


Date: 12/15/05

**PERMIT EXPIRES 5 YEARS FROM ABOVE DATE**

**This permit is subject to revocation if site plans or intended use change.**

Signed: [Signature] Environmental Health Specialist

DRAWING NTS



\* MAINTAIN ALL SETBACKS

\* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22461. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

SHERITA KELLY 919-630-0408  
Name Telephone #

413 E. JACKSON BLVD. ERWIN NC 28339  
Address

1244 MOORE'S CHAPEL RD  
Property Location SR# Road Name

SPRING HILL 2 4 (480 sqd) .942 ac  
Subdivision Lot # # Bedrooms Proposed Lot Size

**TYPE OF SYSTEM**

New Installation  Repair  Septic Tank  Nitrification Lines

Conventional  Other \_\_\_\_\_

Basement  With Plumbing  Without Plumbing

Water Supply:  Well  Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 1 Length of lines 460 Ft.

Width of ditches 3 ft. Depth of ditches 17-20 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] RS  
Signature of Authorized Agent for Harnett County

12/15/05  
Date