

**HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH PERMIT
TO CONSTRUCT A DRINKING WATER SUPPLY WELL**

Application #: 06-5-14598RR PIN #: 9546-90-4213.000 Parcel #: 09 9546 0046 02


Property Owner: Keisha Steadman Address: 122 Lizzie Jeter Lane Cameron N.C. 28326

Type of Facility Served by Well: SFD Sewage System: Conventional

General Conditions of Permit

- Drinking water supply well construction must meet 15A NCAC 02C.100 rules
- The permitted drinking water supply well shall be located in accordance with the **SITE PLAN**
- **ANY ALTERATION** of the site of the site (including location of structures and appurtenance) or modification in use of the well, may subject this Permit to revocation

- Top part of casing to be replaced or the hole in its side to be permanently sealed
- Replace old lid with new one with plumbing exiting the top with proper well seal
- Outside of well casing to be grouted properly if not already



Authorized State Agent

Bryan M. Swain, R.S.

Date 9/11/2008