

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Douglas Ayers PROPERTY LOCATION: High Field Lane  
NEW ☒ REPAIR ☐ EXPANSION ☐ SUBDIVISION: Johnny Faircloth LOT # 3  
Type of Structure: Mod - 30x76 4 BR Site Improvements required prior to Construction Authorization Issuance: Because of 4 Bedroom home system  
Proposed Wastewater System Type: 25% Reduction system had to change to 25% Reduction system  
Projected Daily Flow: 480 GPD  
Number of bedrooms: 4 Number of Occupants: 8 max  
Basement ☐ Yes ☒ No  
Pump Required: ☐ Yes ☐ No ☒ May be required based on final location and elevations of facilities  
Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well 100 feet Permit valid for: ☒ Five years  
Permit conditions: Meet code for Final layout maintain all setbacks ☐ No expiration  
STUB OUT Plumbing shall be at ground level or higher where shown

Authorized State Agent: Jc Wale Date: 01-15-09 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Douglas Ayers PROPERTY LOCATION: High Field Lane  
FACILITY TYPE: Mod - 30x76 4 BR ☒ New ☐ Expansion ☐ Repair  
Basement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☒ No  
Type of Wastewater System\*\* 25% Reduction system (Initial) Wastewater Flow: 480 GPD  
(See note below, if applicable ☒) 25% Reduction system (Repair)

**Installation Requirements/Conditions**

Septic Tank Size 1000 gallons  
Pump Tank Size \_\_\_\_\_ gallons

Number of trenches 1Exact length of each trench 410 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 18 inches(Trench bottoms shall be level to  $\pm 1/4"$ 

in all directions)

Trench Spacing: 9 Feet on CenterSoil Cover: 6 inches(Maximum soil cover shall not exceed  
36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: \_\_\_\_\_ inches below pipe  
\_\_\_\_\_ inches above pipe

Conditions: \_\_\_\_\_ inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: Jc Wale Date: 01-15-09

Construction Authorization Expiration Date: 01-15-2014

HTE# 07-500-17341RR

Permit # 25226

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Douglas Ayers


PROPERTY LOCATOR: High Field Lane

SUBDIVISION Johnny Farrelth

LOT # 3

Authorized State Agent: Ja LARS

Date: 01-15-09



Please note that system  
will require 410' 125%  
Reduction system due to  
The home being 4 Bedroom  
instead of 3 Bedroom  
Meet onsite  
Maintain All setbacks  
STUB out Plumbing  
shallow, at ground level  
or higher where shown.  
Do not Drive or Park  
on Any part of septic  
System