

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant: 07-5-17753

Address:

Date Evaluated: 11/6-20-07
 2nd 28-07

Proposed Facility: *mod. ~~sewer~~*

Design Flow (.1949): 360

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence/ Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1944 Sapro Class	1945 Reaso Horiz	
1	L 4%	0-18	SL						.3
		18-40	SCL		30" 1.54R 4.2				
2	L 4%	0-18	SL						.5
		18-40	SCL		30" 7.14R 4.2				
3	L 4%	0-21	SL						.4
		21-42	SCL		36" 4.2R 4.2				
4	L 4%	0-20	SL						.4
		20-40	SCL		36" 7.54R 4.2				
5	L 4%	0-22	SL						.4
		22-40	SCL		36" 7.54R 4.2				

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	25%	25%
Site LTAR	.4	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: *[Signature]*
 Others Present:


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM	S-STICKY VS-VERY STICKY
	III	SI-SILT- SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM SICL-SILTY CLAY LOAM	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




LOT # 6

SITE PLAN APPROVAL
 DISTRICT USE RR3
 #BEDROOMS 3
 Date 10/10/03

CLASSIC COVE COURT

260'



3x20
 25' x 20' area
 24" manhole

NEEDS
 CLEAR +
 CONCRETE
 WITH
 IRON.
 *NEEDS
 REVISION
 WITH
 PROPER
 SETBACKS

1092