

**SOIL SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____
 Address: _____
 Proposed Facility: 3 BEDROOM HOUSE Design Flow (.1949): 360 gpd
 Location of Site: _____
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: _____
 Date Evaluated: 12/2/07
 Property Size: _____
 Property Recorded: Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapra Class	.1944 Restr Horiz	
1	L 8% MEASURED	0-28	GLS	VFR NS/MP					PS .5
		28-43	GSL	VFR NS/MP					
		43-48	SBK SCL	FR SS/MP					
2		0-34	GS	VFR NS/MP					PS .5
		34-48	SBK SCL	FR SS/MP					
3		0-43	GS	VFR NS/MP					PS .5
		43-48	SBK SCL	FR SS/MP					
4		0-42	GS	VFR NS/MP					PS .5
		42-48	SBK SCL	FR SS/MP					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	PUMP CON
Site LTAR	.5	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OS
 Others Present: _____

[Handwritten Signature]

SITE PLAN APPROVAL

DISTRICT _____ USE Mod

#BEDROOMS 3

Date 11/27/07 *[Signature]*
Zoning Administrator

42x62
Mod.

Future
30x42 Garage

Blanche T. Todd Living Trust
DB 1353 PG 136

