

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: 08-500-20097

Applicant:

Address:

Date Evaluated:

Proposed Facility: mod

Design Flow (.1949): 26

Property Size:

Location of Site: 011421

Property Recorded:

Water Supply:

Public Individual Well Spring Other

Evaluation Method:

Auger Boring Pit Cut

Type of Wastewater:

Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horz.	
S 2%		0-24	GR SL	VFA 1E					5
		24-70	SDK SCL	FR 1E					
		0-24	GR SL	VFA 1-					5
		24-70	SDK SCL	FR 1E					
		0-18	GR SL	VFA 1-					
		18-30	SDK SCL	FR 1E					4
		30-70	SDK SCL	FR 1E					
		0-24	GR SL	VFA 1E					
		24-70	SDK SCL	FR 1-					4
		0-24	GR SL	VFA 1E					
		24-70	SDK SCL	FR 1E					5

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Gravel	Gravel
Site LTAR	.4	.4

Other Factors (.1946): _____
 Site Classification (.1948): P
 Evaluated By: JLV
 Others Present: