

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: _____
Address: _____
Proposed Facility: 45500000 name Design Flow (.1949): 480 gpd
Location of Site: _____
Water Supply: Public Individual Well
Evaluation Method: Auger Boring Pit
Type of Wastewater: Sewage Industrial Process

Applicant: _____
Date Evaluated: 6/2/09
Property Size: _____
Property Recorded: _____
 Spring Other

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapre Class	.1944 Restr. Horiz	
1	L5 2-5%	0-18"	G S	VFL N3/SP					P5 .5
		18-48"	SBK SCL	FL SS/SP					
2		0-22"	G S	VFL N3/SP					P5 .5
		22-36"	SBK SCL	FL SS/SP					
			HAD @ 36" ROCK						
3		0-19"	G S	VFL N3/SP					P5 .45
		19-41"	SBK SCL	FL SS/SP					
		41"+	NSS/SP						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.45	.45

Other Factors (.1946): _____
Site Classification (.1948): P5
Evaluated By: OS
Others Present: _____
4x90" e 24"