RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2179

1. WELL CONTRACTOR:
Roger W. Jackson
Well Contractor (Individual) Name
Jackson Well Company
Well Contractor Company Name
STREET ADDRESS 5660 McDougald Road
Lillington, North Carolina 27546
City or Town State Zip Code
(910) 893-2372
Area code- Phone number

2. WELL INFORMATION:
SITE WELL ID #(if applicable) 09-5-22929
STATE WELL PERMIT#(if applicable)
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box): Residential Water Supply ☐
DATE DRILLED 1-8-10
TIME COMPLETED 4:00 AM☐ PM☒

3. WELL LOCATION:
CITY: Broadway COUNTY Harnett
Shawn McCracken Lot 26
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)
TOPOGRAPHIC / LAND SETTING:
☒Slope ☐Valley ☐Flat ☐Ridge ☐ Other Elv. 284
(check appropriate box)
LATITUDE 35 28.459
LONGITUDE 79 00.234
May be in degrees, minutes, seconds or in a decimal format
Latitude/longitude source: ☐GPS ☐Topographic map
(location of well must be shown on a USGS topo map and *attached to this form if not using GPS*)

4. WELL OWNER
OWNER'S NAME Jerry R. Little
STREET ADDRESS 2340 Thomas Kelly Rd
Bunnlevel N.C. 28338
City or Town State Zip Code
(919) 258 0104
Area code- Phone number

5. WELL DETAILS:
a. TOTAL DEPTH: 220
b. DOES WELL REPLACE EXISTING WELL? YES☐ NO☒
c. WATER LEVEL Below Top of Casing: 46 FT.
(Use "+" If Above Top of Casing)
d. TOP OF CASING IS 1 FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.
e. YIELD (gpm): 10 METHOD OF TEST Air
f. DISINFECTION: Type HTH Amount 10g

9. WATER ZONES (depth):
From 185 To 186 From ____ To ____
From ____ To ____ From ____ To ____
From ____ To ____ From ____ To ____

8. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From	0	To 98 Ft.	6"	SR21	PVC
From		To Ft.			
From		To Ft.			

7. GROUT:

	Depth		Material	Method
From	0	To 25 Ft.	Sand Cement	Pouring
From		To Ft.		
From		To Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From		To Ft.	in.	in.	
From		To Ft.	in.	in.	
From		To Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From		To Ft.		
From		To Ft.		
From		To Ft.		

10. DRILLING LOG

From	To	Formation Description
0	62	CLAY
62	220	SLATE

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Roger W. Jackson 1-12-10
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Roger W. Jackson
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,
1617 Mail Service Center – Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05