

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ROBERT BECQUET PROPERTY LOCATION: NC27
SUBDIVISION BESSIE PAGE LAND LOT # 2
Type of Structure: MOO (55'x43')
Proposed Wastewater System Type: PUMP TO 25% REDUCTION
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement: No
Pump Required: Yes
Type of Water Supply: Public Well Distance from well 100 feet
Permit valid for: Five years

Authorized State Agent: [Signature] Date: 6/14/10 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: ROBERT BECQUET PROPERTY LOCATION: NC27
SUBDIVISION BESSIE PAGE LAND LOT # 2
Facility Type: MOO (55'x43') New
Basement? No Basement Fixtures? No
Type of Wastewater System: PUMP TO 25% REDUCTION (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable) PUMP TO 25% REDUCTION (Repair)

Installation Requirements/Conditions
Number of trenches 2
Septic Tank Size 1000 gallons Exact length of each trench 120 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6-12 inches
Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe _____ inches above pipe _____ inches total
Conditions: WATER LINE MUST BE 10' FROM SEPTIC SYSTEM. NO UTILITIES MAY ENCRONCH ON INITIAL OR REPAIR AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 6/14/10
Construction Authorization Expiration Date: 6/14/15

HTE# 10-5-24381

Permit # 26127

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: NC27

ISSUED TO: ROBERT BECQUET SUBDIVISION BESSIE PARE LAND LOT # 2

Authorized State Agent: [Signature] REMS (OLIVER TOLKSOOT) Date: 6/14/10

NC 27

DRAWING
NTS

