

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 6/30/2010
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-14	G/LS	VF-NSP					JS/PS
		14-27	SBK/SCI	F-SSP					
		0-11	G/LS	VF-NSP					
		11+	M/C	VF:VSP	10YR 8/1				JS
		0-12	G/LS	VF-NSP					
		10-20							
		12-19	SBK/SCI	F-SSP					
		19+	PM		10YR 8/1 23"				JS
		0-18	G/LS	VF-NSP					PS 4
		18-30	SBK/SCI	F-SSP	10 YR 8/1 30"				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: GT Others Present: BN
Available Space (.1945)	✓	✓	
System Type(s)	250 R60	250 R60	
Site LTAR	22	21	