HTE# 11-5-2616H Harnett county Department of Public Hearth	
Improvement Permit	26484
A building permit cannot be issued with only an Improvement Permit	
ISSUED TO: KEVIN GREGORY SUBDIVISION KENNETH M CAMERON	LOT # 2
NEW A REPAIR C EXPANSION Site Improvements required prior to Construction Auth	
Proposed Wastewater System Type: CONVENTIONAL (Pump)	
Projected Daily Flow:GPDGPD	
Number of bedrooms: Number of Occupants: ~ 8 max	
Basement XYes D No	
Pump Required: Xes Do A May be required based on final location and elevations of facilities Type of Water Supply: D Community A Public Distance from well 100 feet Permit valid for: Permit conditions:	Five years
1 AV 1	
Authorized State Agent: MINA RENS Date: 3 14 11 SEE AD	
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject t the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	TACHED SITE SKETCH in meeting their requirements. This is compliance with the provisions of
Construction Authorization	
<u>Construction</u> <u>Authorization</u>	
(Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. System with the attached system layout.	s shall be installed in accordance
ISSUED TO: KENIN GREGORY PROPERTY LOCATION: NC HWY 27 SUBDIVISION KENNETH M CAMERON	
SUBDIVISION NENNERA II CAMERON	LOT #
Basement? X Yes I No Basement Fixtures? X Yes I No	
Type of Wastewater System** - Pume To CONVENTIONAL (Initial) Wastewater Flow:	400 000
(See note below, if applicable 🗶)	<u> </u>
PUMP TO CONVENTIONAL (Repair)	
Installation Requirements/Conditions Number of trenches 5	
Septic Tank Size 1000 gallons Exact length of each trench 80 feet Trench Spacing:	Feet on Center
Irenches shall be installed on contour at a Soil Cover: 6	inches
Maximum Trench Depth of: 18 inches (Maximum soil cover shall	
(Trench bottoms shall be level to $+/-1/4$ " 36" above the trench bottoms	tom)
in all directions) Pump Requirements:ft. TDH vs GPM	
	inches below pipe
Pump Requirements:ft. TDH vs GPM Aggregate Depth: Conditions:	inches above pipe
	inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.	
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of t	
	his permit.
Owner/Legal Representative Signature:	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transforred when they is a here in a start for the site plan, plat, or the intended use changes.	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ov	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ov	mership of the site. This

