

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 4 BGD 808W Design Flow (.1949): 480 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

Property Size:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
1	LS 5-20	0-19	G LS	VFA NS/HP					
		19-36	SBK CL	FL SS/SP					PS-4
		36"	PM						
2		0-21	G LS	VFA NS/HP					
		21-34	SBK CL	F2 SS/SP					PS-4
		HAZ @ 34"							
3		HAZ @ 8" (ROOTS + ROCKS)							
4		0-10"	G LS	VFA NS/HP					
		10"	SBK CL	F2 SS/SP	10YR 7/2 @ 23"				US
5		0-30"	G LS	VFA NS/HP					
		30-40"	SBK CL	F2 SS/SP					PS-4
		40"	PM						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OS Others Present: BM
Available Space (.1945)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	14	14	

5x80' @ 18"