

PREPARED 5/25/11, 13:59:01
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

SCANNED
5/26/11
DATE
PAGE 23
DATE 5/26/11

ADDRESS . . : 2797 WILL LUCAS RD
CONTRACTOR :
OWNER . . . : GRISSOM MICHAEL AND PATRICIA
PARCEL . . . : 01-0544- - -0011- -01-
APPL NUMBER: 11-50026405 CP MODULAR HOME
DIRECTIONS : GO S ON 210 TO DOLLAR STORE ON THE LEFT
JUST BEFORE DOLLAR STORE LEFT ON SHADY
GROVE RD GO TO T TURN LEFT ON ELLIOT
BRIDGE RD GO TO FORK IN RD AND TAKE
RIGTH FORK THAT IS WILL LUCAS RD THE
PROPERTY IS ON THE RIGHT IN ABOUT A
HALF MILE BEFORE YOU GET TO THE S/D
THERE IS A DRIVE STARTED

SUBDIV:
PHONE :
PHONE : (910) 875-4853

STRUCTURE: 000 000 28X76 3BDR MOD W/ GARAGE - BASEMENT
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 SEPTIC - EXISTING? : NEW
WATER SUPPLY : COUNTY

PERMIT: CPPR 00 CP PLUMBING RESIDENTIAL
REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R131 01 5/26/11 TI ONE TRADE FINAL VRU #: 002085421
5/26/11 AS DI

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Michael & Patricia Grissom

Building: _____

Electrical: _____

Address: 2797 Will Lucas Rd

Insulation: _____

Linden, NC 28356

Plumbing: _____

Mechanical: 11-50026405

MFG Home: _____

Date: 11/14/11

Building Official: [Signature]

X

11-2005-11

12-1-1985
W.C. 1985

12-1-1985
W.C. 1985

12-1-1985

11-2005-11

PREPARED 11/14/11, 15:27:35
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 11/14/11

ADDRESS . : 2797 WILL LUCAS RD SUBDIV:
CONTRACTOR : HOMES BY VANDERBUILT PHONE : (919) 774-6319
OWNER . . : GRISSOM MICHAEL AND PATRICIA PHONE : (910) 875-4853
PARCEL . . : 01-0544- - -0011- -01-
APPL NUMBER: 11-50026405 CP MODULAR HOME

DIRECTIONS : GO S ON 210 TO DOLLAR STORE ON THE LEFT
JUST BEFORE DOLLAR STORE LEFT ON SHADY
GROVE RD GO TO T TURN LEFT ON ELLIOT
BRIDGE RD GO TO FORK IN RD AND TAKE
RIGTH FORK THAT IS WILL LUCAS RD THE
PROPERTY IS ON THE RIGHT IN ABOUT A
HALF MILE BEFORE YOU GET TO THE S/D
THERE IS A DRIVE STARTED

STRUCTURE: 000 000 28X76 3BDR MOD W/ GARAGE - BASEMENT

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 SEPTIC - EXISTING? : NEW
WATER SUPPLY : COUNTY

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	7/15/11 7/15/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002108959 T/S: 07/14/2011 08:54 AM VBROWN ----- 2797 WILL LUCAS RD LINDEN 28356----- T/S: 07/15/2011 12:03 PM TWARD -----
B103 01	7/15/11 7/15/11	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002108942 T/S: 07/14/2011 08:54 AM VBROWN -----
B117 01	8/08/11 11/10/11	JH AP	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 002159390
C173 01	8/18/11 8/18/11	JH AP	C*MODULAR INSPECTION VRU #: 002124626 marriage wall inspection. 119
H824 01	8/22/11 8/22/11	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002127231 T/S: 08/23/2011 08:29 AM SZIMMER ----- T/S: 08/23/2011 08:29 AM SZIMMER -----
R429 01	11/10/11 11/10/11	DT DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002160174 1. Need house numbers. 2. Unlabeled breakers in panel T/S: 11/10/2011 02:25 PM DETAYLOR -----
B117 02	11/14/11 11/14/11	DT CA	R*MODULAR ROUGH-IN VRU #: 002160430 electrical and building final. verify house numbers installed and that panel is labeled. Re inspection. Call David 919-353-9280 with any questions Should be final insp. T/S: 11/14/2011 11:51 AM DETAYLOR -----
R429 02	11/14/11 <i>11/14/11</i>	TI <i>AP DT</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002161255

----- COMMENTS AND NOTES -----

PREPARED 11/10/11, 14:07:53
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 12
DATE 11/14/11

ADDRESS . . : 2797 WILL LUCAS RD SUBDIV:
CONTRACTOR : HOMES BY VANDERBUILT PHONE : (919) 774-6319
OWNER . . : GRISSOM MICHAEL AND PATRICIA PHONE : (910) 875-4853
PARCEL . . : 01-0544- - -0011- -01-
APPL NUMBER: 11-50026405 CP MODULAR HOME
DIRECTIONS : GO S ON 210 TO DOLLAR STORE ON THE LEFT
JUST BEFORE DOLLAR STORE LEFT ON SHADY
GROVE RD GO TO T TURN LEFT ON ELLIOT
BRIDGE RD GO TO FORK IN RD AND TAKE
RIGTH FORK THAT IS WILL LUCAS RD THE
PROPERTY IS ON THE RIGHT IN ABOUT A
HALF MILE BEFORE YOU GET TO THE S/D
THERE IS A DRIVE STARTED

STRUCTURE: 000 000 28X76 3BDR MOD W/ GARAGE - BASEMENT
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 SEPTIC - EXISTING? : NEW
WATER SUPPLY : COUNTY

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	7/15/11 7/15/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002108959 T/S: 07/14/2011 08:54 AM VBROWN ----- 2797 WILL LUCAS RD LINDEN 28356----- T/S: 07/15/2011 12:03 PM TWARD -----
B103 01	7/15/11 7/15/11	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002108942 T/S: 07/14/2011 08:54 AM VBROWN -----
B117 01	8/08/11 11/10/11	JH AP	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 002159390
C173 01	8/18/11 8/18/11	JH AP	C*MODULAR INSPECTION VRU #: 002124626 marriage wall inspection. 119
H824 01	8/22/11 8/22/11	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002127231 T/S: 08/23/2011 08:29 AM SZIMMER ----- T/S: 08/23/2011 08:29 AM SZIMMER -----
R429 01	11/10/11 <i>11/10/11</i>	TI <i>DAVID</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002160174
B117 02	11/14/11 <i>11/14/11</i>	TI <i>CAW</i>	R*MODULAR ROUGH-IN VRU #: 002160430 electrical and building final. verify house numbers installed and that panel is labeled. Re inspection. Call David 919-353-9280 with any questions

----- COMMENTS AND NOTES -----

PREPARED 11/10/11, 11:32:05
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 11/10/11

ADDRESS . . : 2797 WILL LUCAS RD SUBDIV:
CONTRACTOR : HOMES BY VANDERBUILT PHONE : (919) 774-6319
OWNER . . : GRISSOM MICHAEL AND PATRICIA PHONE : (910) 875-4853
PARCEL . . : 01-0544- - -0011- -01-
APPL NUMBER: 11-50026405 CP MODULAR HOME

DIRECTIONS : GO S ON 210 TO DOLLAR STORE ON THE LEFT
JUST BEFORE DOLLAR STORE LEFT ON SHADY
GROVE RD GO TO T TURN LEFT ON ELLIOT
BRIDGE RD GO TO FORK IN RD AND TAKE
RIGTH FORK THAT IS WILL LUCAS RD THE
PROPERTY IS ON THE RIGHT IN ABOUT A
HALF MILE BEFORE YOU GET TO THE S/D
THERE IS A DRIVE STARTED

STRUCTURE: 000 000 28X76 3BDR MOD W/ GARAGE - BASEMENT
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 SEPTIC - EXISTING? : NEW
WATER SUPPLY : COUNTY

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	7/15/11 7/15/11	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002108959 T/S: 07/14/2011 08:54 AM VBROWN ----- 2797 WILL LUCAS RD LINDEN 28356----- T/S: 07/15/2011 12:03 PM TWARD -----
B103 01	7/15/11 7/15/11	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002108942 T/S: 07/14/2011 08:54 AM VBROWN -----
B117 01	8/08/11 11/10/11	JH AP	R*MODULAR ROUGH-IN TIME: 17:00 VRU #: 002159390
C173 01	8/18/11 8/18/11	JH AP	C*MODULAR INSPECTION VRU #: 002124626 marriage wall inspection. 119
H824 01	8/22/11 8/22/11	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002127231 T/S: 08/23/2011 08:29 AM SZIMMER ----- T/S: 08/23/2011 08:29 AM SZIMMER -----
R429 01	11/10/11 <i>11/10/11</i>	TI <i>DA-D</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002160174

COMMENTS AND NOTES
