HTE# 12-5-3000 )

## Harmet County Department of Public ... alth

**Improvement Permit** 

27192

A building permit cannot be issued with only an improvement Permit PROPERTY LOCATION: YOUTERSON SUBDIVISION BUTLER EXPANSION Site Improvements required prior to Construction Authorization Issuance: NEW X (32×80' Home Type of Structure: 25% REDUCTION Proposed Wastewater System Type: Projected Daily Flow: Number of bedrooms: Basement Yes No No ☐ May be required based on final location and elevations of facilities Pump Required: ☐Yes Type of Water Supply: 

Community 

Public 

Well Distance from well 

feet Permit valid for: Five years ■ No expiration Permit conditions: SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the ssuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PATTERSON PROPERTY LOCATION: DARROCH RO ISSUED TO: BARRADA SUBDIVISION BUTLEZ Facility Type: MAN. Home (32780) X New Expansion - Repair Basement Fixtures? | Yes | X No | (Initial) Wastewater Flow: 480 GPD Type of Wastewater System\* (See note below, if applicable 

) 20% REDUCTION Number of trenches Installation Requirements/Conditions Exact length of each trench 80 feet Trench Spacing: Septic Tank Size 1000 gallons Trenches shall be installed on contour at a Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. GPM inches below pipe inches above pipe Aggregate Depth: inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the lite plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provision of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date:

## Harnett County Department of Public Health Site Sketch

