

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant: *Smith*  
 Address:                      Date Evaluated:  
 Proposed Facility: *MED + Bath*      Design Flow (.1949):      Property Size:  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual       Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 34%	0-20	SL	fine sand					
		20-40	SL-clay	fine sand	36-38" 2.5-3.0				.35
2	L 4%	0-20	SL	fine sand					
		20-40	SL-clay	fine sand	38-40" 2.5-3.0				.4
3	L 4%	0-12	SL	fine sand					
		12-40	SL-clay	fine sand	36" 2.5-3.0				.35

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): <i>P3</i>
System Type(s)	<i>25%</i>	<i>25%</i>	Evaluated By: <i>[Signature]</i>
Site LTAR	<i>.35</i>	<i>.35</i>	Others Present: