

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *Henett*
 Address: Date Evaluated: *5-21-17*
 Proposed Facility: *POD* Design Flow (.1949): *4.80* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	L-40%	0-30	SL	ALCANSP					
		30-48	SC-cing	fm 150L S.P.	40" 7.5% 31				-4
4	L-42	0-5	SLDM	ALCANSP					
		5-18	SC-cing	fm 150L S.P.	15" mst Mud				.2
5	L-43	0-6	SL	ALCANSP					
		6-24	SC-cing	fm 150L S.P.	22" 24" - 1 1/2" mst 31				.25

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>[Signature]</i> Others Present:
Available Space (.1945)			
System Type(s)	<i>264</i>	<i>264</i>	
Site LTAR	<i>.4</i>	<i>.25-28</i>	