

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Clark
 Address: Date Evaluated: 3-5-10-15-20-25-30-4-1-11
 Proposed Facility: NOT Design Flow (.1949): 480 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 4%	0-18	SL	ENG SAND					
		18-30	SL	ENG SAND	46-48	25M 3A			4
		30-40	SC-CRAG	ENG SAND					
2	L 4%	0-20	SL	ENG SAND					
		20-46	SC-CRAG	ENG SAND	42	75M 3A			4
3	L 4%	0-22	SL	ENG SAND					
		22-40	SC-CRAG	ENG SAND	42	75M 3A			4
4	L 5%	0-20	SL	ENG SAND					
		20-44	SC-CRAG	ENG SAND	42	75M 3A			4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)			
System Type(s)	<u>75M</u>	<u>75M</u>	
Site LTAR	<u>4</u>	<u>4</u>	