

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD - Modular

Name: Daly Homes

Address: 690 Kirk Adams Rd

Angier, N.C. 27501

Date: 8.26.15

Building Official: Brad J. [Signature]

Permit Numbers

Building: 15-50036010


Electrical: " "

Insulation: " "

Plumbing: " "

Mechanical: " "

MEG Home: _____



 ADDRESS : 32031 *UNASSIGNED
 CONTRACTOR : DALY HOMES
 OWNER : MASTER DEVELOPERS II LLC
 PARCEL : 04-0692- - -0039- - -
 APPL NUMBER: 15-50036010 CP MODULAR HOME
 DIRECTIONS : T/S: 04/28/2015 02:08 PM LBENNETT --
 HWY 210 TOWARD ANGIER, R ON HWY 55 @
 WILCO HESS; L ON BENSON RD @ 2 GALS
 PRINTING; R ON KIRK ADAMS RD.; CULDASAC
 @ END OF RD, PROCEED ONTO DIRT RD,
 FIRST DRIVEWAY ON THE RIGHT.
 PREMISE#:17663427
 SUBDIV: D A LANGDON
 PHONE : (949) 751-0622
 PHONE :

STRUCTURE: 000 000 76X26.8 4BDR OFF FRAME
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 SEPTIC - EXISTING? : NEW
 WATER SUPPLY : WELL

PERMIT: CPMH 00 CP MODULAR

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/15	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002676508
	6/19/15	AP	T/S: 07/08/2015 12:39 PM DJOHNSON
A814 01	7/02/15	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002681989
	7/02/15	AP	690 KIRK ADAMS RD ANGIER 27501
			T/S: 07/02/2015 11:47 AM SBENNETT
B103 01	7/02/15	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002681971
	7/02/15	AP	someone needs to sign off on the footing inspection - it is still open
			T/S: 07/02/2015 02:49 PM DETAYLOR
B119 01	7/09/15	BS	R*MOD MARRIAGE WALL TIME: 17:00 VRU #: 002685477
	7/09/15	AP	T/S: 07/08/2015 12:39 PM DJOHNSON
			T/S: July 09, 2015 10:08 AM BSUTTON
H824 01	7/17/15	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002689982
	7/17/15	DA	PER JAMES MANHART OPERATIONS PERMIT ON HOLD. NEEDS PUMP AND ALARM CHECKED BEFORE IT CAN BE ISSUED. CALL HIM 893-7547 WHEN THIS IS READY TO BE INSPECTED.
			T/S: 07/17/2015 09:43 AM SSTEWARD
R425 01	7/31/15	BS	FOUR TRADE ROUGH IN VRU #: 002696607
	7/31/15	AP	Rough in inspection for underside plumbing, wiring, HVAC. Please call John at Daly Homes, 919-751-0622 with questions. Thanks.
			T/S: July 31, 2015 03:01 PM BSUTTON
E209 01	8/14/15	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002703478
	8/14/15	AP	T/S: 08/13/2015 02:29 PM DJOHNSON
			T/S: August 14, 2015 11:06 AM BSUTTON
			Need a premise number
H824 02	8/18/15	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002705754
	8/18/15	AP	T/S: 08/19/2015 10:05 AM SSTEWARD
			T/S: 08/19/2015 10:06 AM SSTEWARD
H828 01	8/21/15	JM	ENVIRO. WELL PERMIT TIME: 17:00 VRU #: 002707594
	8/21/15	AP	T/S: 08/24/2015 11:30 AM SSTEWARD
			T/S: 08/24/2015 11:30 AM SSTEWARD
R429 01	8/26/15	TI	FOUR TRADE FINAL VRU #: 002708097
	<u>8.26.15</u>	<u>APBS</u>	Final for c of o. Key in inspection box.

 COMMENTS AND NOTES
