

October 31, 2017

Clayton Homes
Maynard Wilkins
1312 Fayetteville Road
Raleigh, NC 27603

RE: Existing Septic System Inspection HTE# 17-5-42590

Dear Mr. Wilkins,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal.
Tank was not uncovered. (\$25.00 return tip fee incurred.)

2. Have system pumped out

3. Replace sanitary T

4. Other – Proposed single-family dwelling not flagged.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health OSWW Specialist
Harnett County Department of Public Health
Environmental Health

AC/sgs
Copy - Central Permitting