

HTE #: 17-5-42590

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Clayton Homes of Raleigh Phone #: 919-422-6668

Address: 1312 Fayetteville Road Raleigh, NC 27603

Name of Mobile Home Park or S/D: Lake Pointe S/D

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 89 Lakeview Drive Fuquay-Varina, NC 27526  
Lake Point S/D Lot 34

Purpose of Inspection: Existing Tank - Addition of 3BR (28'x56') Mod. on location of previous MH. Existing Septic Tank and Drainfield not within proposed Mod. placement. Sanitary Tee present.


**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
Signature of Environmental Health Specialist

ANDREW CURRAN, NEHS

11/29/2017  
Date