

SITE/S EVALUATION FOR ON-SI WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES													
		1	2	3	4	5	6	7	8	9	10				
LANDSCAPE POSITION	.1940														
SLOPE (%)	.1940	10%													
HORIZON 1 DEPTH		0-30	0-6	0-40	0-10										
Texture Group	.1941(A)(1)	LS/SL	LS/SL	LS	LS	SL									
Consistence	.1941	VFR		VFR											
Structure	.1941(A)(2)	G		G											
Mineralogy	.1941(A)(3)	NS/NP		NS/NP											
HORIZON 2 DEPTH			6-30		10-34										
Texture Group	.1941(A)(1)		SCL		C	SCL									
Consistence	.1941		FR												
Structure	.1941(A)(2)		SBK												
Mineralogy	.1941(A)(3)		SS/SP												
HORIZON 3 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
HORIZON 4 DEPTH															
Texture Group	.1941(A)(1)														
Consistence	.1941														
Structure	.1941(A)(2)														
Mineralogy	.1941(A)(3)														
SOIL WETNESS	.1942	21"	27"	38"		32"									
RESTRICTIVE HORIZON	.1944				HAR @ 34"										
SAPROLITE	.1943/.1956														
CLASSIFICATION	.1948	US	PS	S	PS	PS									
LONG TERM ACCEPTANCE RATE	.1955	4.5	.3	1	.3	.5									

+30' APPROXIMATE SCOPED #5 HARE @ 40" LAT H₂O ABOVE

