

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: 20613
 Address: _____ Date Evaluated: 8-4-5-6-08
 Proposed Facility: SOD Design Flow (.1949): 360 Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring PH Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	1940 Indicating Position/ Slope %	Particle Depth (IN)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Class (177)
			Soil Structure/ Texture	Consistence/ Mineralogy	Water Color	Depth (IN)	Class	Notes	
1	L 8%	0-12	SL	FR GR NSNP					.3
		12-30	SCL	SFR 15% NSNP					
		30-48	SL	FR GR NSNP					
2	L 8%	0-16	SL	FR GR NSNP					.3
		16-32	SCL	SFR 18% NSNP					
		32-48	SL	FR GR NSNP					
3	L 7%	0-14	SL	FR GR NSNP					.3
		14-30	SCL	SFR 17% NSNP					
		30-48	SL	FR GR NSNP					
4	L 4%	0-48	SL	FR GR NSNP					.4
5	L 4%	0-42	SL	FR GR NSNP					.4
		42-48	SL	FR 17% NSNP					
6	L	0-48	SL	FR GR NSNP					.4

Description	Initial System	Repair System
Available Space (.1945)		/
System Type(s)	15" W	15" W
Site LTAR	.4	.3

Other Factors (.1946): _____
 Site Classification (.1948): OS
 Evaluated By: [Signature]
 Others Present: [Signature]