

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 7/9/2012
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
	LS690	6-18	G/SL	VFNMP					PS
		18-30	SBK/SC1	F:SSSP	at surface				
		6-22	G/LS	VFNMP					
		22-43	SBK/SC1	F:SSSP	10xR71, 4"				PS, 4
		0-17	G/LS	VFNMP					
		17-40	SBK/SC1	F:SSSP	10xR71, 38"				PS, 4
		0-21	G/LS	VFNMP					
		21-38	SBK/SC1	F:SSSP	10xR71, 38"				PS, 35

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BM Others Present:
Available Space (.1945)			
System Type(s)	25%	25%	
Site LTAR	.35	.4	