

HTE# 08-5-20121

Harnett County Department of Public Health

24817

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: TWR VENTURES, LLC PROPERTY LOCATION: Hwy 401N
 NEW REPAIR EXPANSION SUBDIVISION: TRISOUTH INDUSTRIAL PARK LOT # 4
 Type of Structure: INDUSTRY - METAL BUILDING 120'x60' Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCTION SYSTEM
 Projected Daily Flow: 450' GPD
 Number of bedrooms: _____ Number of Occupants: 18 employees
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Markham Date: 6-24-08 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: TWR VENTURES, LLC PROPERTY LOCATION: Hwy 401N
120'x60' SUBDIVISION: TRISOUTH INDUSTRIAL PARK LOT # 4
 Facility Type: INDUSTRY METAL BUILDING New Expansion Repair
 Basement? Yes No Basement Fixtures: Yes No
 Type of Wastewater System** PUMP TO 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 450 GPD
 (See note below, if applicable) PUMP TO 25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions Number of trenches 3
 Septic Tank Size 1000 gallons Exact length of each trench 133' feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
MANHOLE SPACES 3-1/2" x 40" Maximum Trench Depth of: 20'-7 1/8" inches (Maximum soil cover shall not exceed
2' HEAD ROOM (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
0" VALVES _____ inches above pipe
 Conditions: _____ 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham Date: 6-24-08
 Construction Authorization Expiration Date: 6-24-13

