

COMMENTS:

*SITE VISIT ON 8/27/08 BY OT, JM, BM. PLUMBING STUBBED OUT AT

LOCATION OTHER THAN SPECIFIED ON PERMIT.

- NEW CA TO BE ISSUED DUE TO NEW TANK LOCATION REQUIRED

- NEW TANK LOCATION MAY REQUIRE TRAFFIC RATED TANK

- SUPPLY ^{LING} MAY NEED TO BE S ^{AS REQUIRED} LEEVED DUE TO DEPTH

- DRAINFIELD ^{+ REPAIR} TO BE FENCED OFF DUE PROXIMITY TO DRIVE

- IF PROPER FALL FROM TANK TO DRAINFIELD CANNOT BE MAINTAINED

A PUMP WILL BE REQUIRED