

HTE 03-5-5991

IMPROVEMENT PERMIT

20681

Replaces # 19922

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Oak Ranch
Property Location: SR# Buckhorn Rd
New Installation [checked]
Septic Tank [checked]
Repairs [unchecked]
Nitrification Line [checked]

Subdivision Oak Ranch Lot #

Tax ID # Quadrant #

Number of Bedrooms Proposed: Storage Building Lot Size:

Basement with Plumbing: [unchecked] Garage: [unchecked] Storage with Restroom

Water Supply: [unchecked] Well [unchecked] Public [unchecked] Community

Distance From Well: ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [checked] Conventional [unchecked] Other

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons

Subsurface Drainage Field: No. of ditches 1 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain Required: Linear feet

Date: 3-10-04

Signed: [Signature] Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

existing Bldg

existing Drain Field

