

Oliver Tolksdorf

From: www-data [www-data@dehnet.net] on behalf of joe.pearce@ncmail.net
Sent: Tuesday, December 03, 2002 8:53 AM
To: Oliver Tolksdorf
Cc: bill.jeter@ncmail.net; kevin.neal@ncmail.net
Subject: Re: Auto Repair Shop w/ floor drains

Mr. Tolksdorf,
The floor drains in an auto repair shop require State Approval as they are considered Industrial Process Wastewater. We will not grant such approval to ensure compliance with the Federal Prohibitions on Underground Injection Control from Vehicle Maintenance Facilities and as it is an unreasonable risk to groundwater. The drains cannot be connected to a septic system. Feel free to have the owner call me. So don't permit it, and don't issue a CO. If the city wants to connect it to their sewer system then they can.

Sincerely yours,
Joe Pearce
Quoting Oliver Tolksdorf <otolksdorf@harnett.org>:

> Mr. Pearce,
>
> I have an application for an auto repair shop with one restroom and two
> floor drains. What is the process for getting that establishment
> permitted
> since it has floor drains? The municipality has already issued them
> their
> building permit and the building is up. Not that that really makes a
> difference but just something I thought I'd pass along. Thanks for your
> help.
>
> Respectfully,
> Oliver Tolksdorf
> Soil Scientist
> Harnett County
>
>

Joe Pearce
phone (919) 715-3270
fax (919) 715-3227
e-mail <joe.pearce@ncmail.net>

SPOKE WITH Mr. NORMAN AVERY ON 12/4/02. DIRECTED HIM TO MR. PEARCE
BASED ON THE ABOVE E-MAIL. MR AVERY STATED THAT MIKE THOMPSON
SAID HE WOULD NEED AN OIL-WATER SEPARATOR.

