SITE/S . EVALUATION FOR ON-S WASTEWATER

APPLICANT NAME _____ DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L								
SLOPE (%)	.1940	2	2								
HORIZON 1 DEPTH		0-10	0-10								
Texture Group	.1941(A)(1)	SL	SL								
Consistence	.1941	Fr	Fr								
Structure	.1941(A)(2)	GR	GR								
Mineralogy	.1941(A)(3)	NSNP	NSNP								
HORIZON 2 DEPTH		10-38	10-38								
Texture Group	.1941(A)(1)	SCL	SCL								
Consistence	.1941	SL Firm	SL Firm								
Structure	.1941(A)(2)	ABK	ABK								
Mineralogy	.1941(A)(3)	SSSP	SSSP								
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	30	30								
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS	PS								
LONG TERM ACCEPTANCE RATE	.1955	.35	.35								


Septic
to
Self
to
Highest Ground
Home
23'
72'