

05-5-5043

Harnett County Central Permitting
PO Box 65 Lillington, NC 27546

Telephone Number 910-893-4759

Application for Environmental Health Improvement Permit in Areas Zoned by Municipalities

Landowner Information:

Name: Franklin McLeod

Address: Aurora, NC

Phone: _____

Applicant Information:

Name: Larry Norris

Address: PO Box 727
Dunn, NC 28334

Phone: 910-892-4345

Property Location:

E911 Address: 60 Queen Crest

State Road #: ~~Highway 269~~ Lot/Tract Size: _____

Subdivision: Stockton Lot #: 40

Give Specific directions to the property from Lillington: 40 toward Angier
about 1 mile on left before Angier.

Proposed Use:

- Single Family Dwelling (Size 28 X 52) # of Bedrooms 3
Basement _____ Basement w/plumbing _____ Deck 12x14
patio
- Multi-Family Dwelling - # of Units _____ # of Bedrooms/Units _____
- Manufactured Home (Size _____ X _____) # of Bedrooms _____ Garage _____
Deck _____
- Number of Persons per Household 4
- Business - Square Footage Retail Space _____ Type _____
- Industry - Square Ft. _____ Type _____
- Home Occupation - # of Rooms/Size _____ Use _____
- Addition to Existing Building - Size _____ Use _____
- Other _____

Water Supply: County Well Other

Sewer: Septic Tank (Existing? _____) County Other

Applicant's Signature Larry Norris

#036741(N

LAND USE AND PROPERTY DESCRIPTION
TOWN OF ANGIER, N. C.

APPLICATION FOR :

- Improvement permit
- Mobile Home lot
- Conditional Use
- Parking permit
- Satellite Dish Antenna
- Signs
- Fences
- Zoning of Property
- Subdivision Approval
- Mobile Home Park
- Grading permit
- Temporary permit
- Special Use _____
- Other _____

APPLICANT:

Name Millennium Homes of NC
 Address P.O. Box 727
Dunn NC 28334
 Phone 910 892 4345

OWNER:

Name Same
 Address _____
 Phone _____

PRESENT USE OF PROPERTY Vacant lot

LOCATION OF PROPERTY Lot # 40 Stockton

PROPOSED USE OF PROPERTY

- Single Family Dwelling : # Rooms 8 # Bedrooms 3 Square feet _____
- Multi Family Dwelling: # of units _____ #Bedrooms (per unit) _____
square feet (per unit) _____
- Mobile Home (single lot): single wide _____ double wide _____
- Mobile Home Park: Section 16, Zoning Ordinance must apply
- Business: total # of employees per day _____
Type of business _____
- Others (specify) _____
- Existing structure _____ Renovate _____ Addition _____
Demolish _____

Attach site plan showing property lines, location of proposed structures (including driveways, ratios, decks, etc.) and any existing structure.

WATER & SEWER SUPPLY:

	<u>WATER</u>	<u>SEWER</u>
Private	_____	<input checked="" type="checkbox"/> _____
Public	<input checked="" type="checkbox"/> _____	_____
Proposed	_____	_____
Existing	_____	_____


APPLICANT: I certify that all of the statements made in this application and any attached documents are true, complete and correct to the best of my knowledge and belief and are made in good faith. I understand that false information may be grounds for rejection of this application. Authorized Inspection Department Representatives are granted right of entry to make evaluations or inspections and to release information upon public request.

House Footprint: 30' x 50' (No Foundation Drain)
 Bedrooms: 3

Initial System: 2 x 150 gravity driven conventional
 on contour at: 18-24 inches
 LTAR: 0.4 gpd/sqft
 Repair System: 4 x 80' gravity driven innovative
 on contour at: 12 inches
 LTAR: 0.3 gpd/sqft

LEGEND

★	EIP	□	Septic Tank
⌊	Step-down	■	Pump Tank
⊙	Proposed Well	○	D-Box
⊗	Existing Well	⊠	Pressure Manifold



Lines flagged at site on 9-ft centers.

Initial/Repair	Line #	Color	Drainline Length(ft)	Measured Field Line Length (ft)	Relative Elevation (ft)
Initial	1	B	50	72	104.52
Initial	2	Y	50	71	104.18
Initial	3	R	50	58	103.72
Initial	4	B	70	76	103.37
Initial	5	Y	80	83	103.05
Repair	6	R	80	96	102.63
Repair	7	B	80	110	101.74
Repair	8	Y	80	95	100.84
Repair	9	R	80	83	100.29
Total:			620	744	EIP=100

HAL OWEN & ASSOCIATES, INC.

SOIL & ENVIRONMENTAL SCIENTISTS

P. O. Box 400, 266 Old Coats Road

Lillington, NC 27546

Phone (910) 893-8743 / Fax (910) 893-3594

E-mail: halowen@intrstar.net

12 June 2002

Mr. Lester Stancil
Stancil & Associates
Registered Land Surveyors, P. A.
P.O. Box 730
Angier, NC 27501

Reference: Stockton Subdivision – Lots 40 & 41
Site Investigation and Septic System Design

Dear Mr. Stancil,

A site investigation and septic system layout was conducted for the above referenced property which is located on the east side of NC Highway 210, Black River Township, Harnett County, North Carolina. The purpose of this investigation was to demonstrate the ability of each of these lots to support a subsurface sewage waste disposal system and 100% repair. Public water supplies will be utilized at this site. Foundation Drains do not appear possible on either lot. Lot 40 has a proposed design of two 150-ft gravity driven conventional drainlines for the initial system. An innovative system is proposed for the repair, which utilizes four 80-ft lines. Lot 41 is proposed with a pump system to six 50-ft conventional drainlines for the initial system. The repair consists of two 150-ft conventional drainlines, which will also require a pump. Attached are the septic system designs for Lots 40 & 41 that you could submit to the Harnett County Health Department to aid in the permitting process. This report represents my professional opinion but does not guarantee or represent permit approval for any lot by the local Health Department.

The septic system has been demonstrated with various colored pin flags that are located on the lot. **It is important that you do not disturb the septic system area. It is recommended that a protective fence or staked line be placed around the system prior to construction to eliminate any potential damage to the soil or the layout of the system.**

I appreciate the opportunity to provide this service and hope to be allowed to assist you again in the future. If you have any questions or need additional information, please contact me at your convenience.

Sincerely,



Laura J. Fortner


Soil Scientist in Training III



Click on the Map to:

ZoomIn ZoomOut Recenter Map Identify: Tax Parcels

Zoom Factor: 2X Radius Search (feet) 200



Parcel Data

Find Adjoining Parcels

- Account Number:000408924000
- Owner Name: MCLEOD B FRANKLIN & WIFE
- Owner/Address 1: MCLEOD ELAINE P &
- Owner/Address 2: MCLEOD W STEWART & TAMMY C
- Owner/Address 3: 6513 WAKEFALLS DRIVE
- City,State Zip: WAKE FOREST ,NC 275870000
- Commissioners District: 4
- Voting Precinct: 401
- Census Tract: 401
- Flood Zone:
- Firm Panel:
- In Town:
- Fire Ins. District: Black River
- School District: 3

- PIN: 0673-27-1369.000
- Parcel ID: 040672 0104 44
- Legal 1:LOT#41 STOCKTON S/D
- Legal 2:PC#F/436-D
- Property Address: QUEENS CT 001116 X
- Assessed Acres: .45AC
- Calculated Acres: .47
- Deed Book/Page: 1324/0790
- Deed Date: 1999/01/21
- Revenue Stamps: \$. 0
- Year Built: 1000
- Building Value: \$0.00
- Land Value: \$18,000.00
- Assessed Value: \$18,000.00

SCALE 1 : 5262

Reference Map

Map Layers

Draw Layers

Draw selected layers:

Boundary

- Commissioners Districts
- Fire
- Tax Parcels
- Townships
- Rescue
- Flood Zones
- Multi Symbol
- Precincts

Infrastructure

- Major Roads
- Water Pipes

Physical

- E911 Streets
- Rivers

Draw Layers

MAP Currency

This map is prepared for the inventory of real property found within this jurisdiction, and is compiled from recorded deeds, plats, and other public records and data. Users of this map are hereby notified that the aforementioned public primary information sources should be consulted for verification of the information contained on this map. The Harnett County, mapping, and software companies assume no legal responsibility for the information contained on this map or in this website.

Data Effective Date:
6/20/2002 3:03:46 PM
 Current Date: **7/2/2002**
 Time: **3:01:13 PM**

Harnett County - Property Description Inquiry Functions Help

7/17/2002 2:59:11 PM

Location ID	27851
PARCEL NUMBER	04-0673 - 0104-44
PIH	0673-271369 000
Location address	UNASSIGNED 04
Primary related party	HCLEGG B FJR IM DB FRANKLIN

Property description
 LOT#41 STOCKTON S/D
 PC#F/436-D

OK Cancel Exit Get party data