

0550013319

1079889

HARNETT COUNTY CENTRAL PERMITTING  
PO Box 65 Lillington, NC 27546  
910-893-4759 Fax: (910) 893-2793

New - pd. \$150.00

See below

APPLICATION FOR EXISTING SEPTIC SYSTEM INSPECTION FOR  
SINGLE FAMILY DWELLING

Date: 10/26/05

Telephone: (910) 893-8181 Fax: ( ) \_\_\_\_\_  
E-Mail: \_\_\_\_\_

Applicant: Joseph Boone  
Mailing Address: 1578 US 421 N  
City: Lillington Zip Code: 27546

Property Owner: John D. Mason (As listed in Tax Office)  
Property Address: 1934 Old US 421  
State Road Number: 1291 Lot Number: \_\_\_\_\_

Name of Subdivision: \_\_\_\_\_ (If Applicable)

Directions (please give concise, complete directions from Lillington, N.C.)  
take Old US 421 Out Lillington about 1.5-2 miles  
property is on the Right

~~There is a \$25.00 charge for this service. This approval is subject to revocation if the intended use of the septic system changes or if false information is provided on this application.~~

Your signature below certifies that all above information is correct.

\* Signature of Owner, Authorized Agent or Applicant: Joseph a Boone


<b>FOR OFFICE USE ONLY</b>	
Authorization for Use of Existing Septic System	
Signature of Environmental Health Specialist	Date

\* Customer wants to move lines on existing septic tanks  
09/03 - See site plan for proposed area for septic lines  
- Customer paid \$150 for new evaluation

10/28 S

1-60

618 US 421



He is seeking this area on this side  
 Seph this area on this side

would like to put system in this area  
 Customer Area

*Joseph A. Brown*

SITE PLAN APPROVAL  
 DISTRICT USE RA30 SFD  
 #BEDROOMS 3  
 10/26/05  
 Zoning Administrator  
 Date



7-202-11-2001

I HEREBY CERTIFY THAT THIS RECORD PLAT COMPLIES WITH THE SUBDIVISION REGULATIONS OF HARNETT COUNTY, N.C. AND THAT THIS PLAT HAS BEEN APPROVED FOR RECORDING IN THE REGISTER OF DEEDS HARNETT COUNTY.

12-02 *Shirley J. Jarmore*  
PLANNING DIRECTOR

THE LOT(S) ON THIS PLAT HAVE BEEN EVALUATED BY A PRIVATE CONSULTANT, BASED ON THIS REVIEW, IT APPEARS THAT LOT(S) ON THIS PLAT MEET APPROPRIATE REGULATION. NOTE THAT FINAL APPROVAL FOR EACH LOT REQUIRES ISSUANCE OF THE APPROPRIATE HARNETT COUNTY HEALTH DEPARTMENT PERMITS FOR DOMESTIC USE AND STORM DRAINAGE IN ACCORDANCE WITH REGULATIONS IN FORCE AT THE TIME OF PERMITTING. THIS CERTIFICATION DOES NOT REPRESENT APPROVAL OR A PERMIT FOR ANY SITE WORK.

DATE: 12/20/01 ENVIRONMENTAL HEALTH

CERTIFICATION OF OWNERSHIP, DESIGNATION AND JURISDICTION

I (we) hereby certify that I am (we are) the owner(s) of the property shown and described hereon and that I (we) hereby adopt this plan of subdivision with my (our) free consent, establish the minimum building setback lines and dedicate all streets, alleys, walks, grades and other sites and easements to public or private use as noted, and all of the same shown herein to within the subdivision regulations jurisdiction of Harnett County except:

12-20 2001 *Robert V. Bennett*  
Date Owner/Agent

NORTH CAROLINA HARNETT COUNTY

I, MICHAEL S. JARROVICH, P.L.S., do hereby certify that this plan was drawn under the supervision and direct observation recorded in Book 358, Page 567, and that the boundaries and surveys are clearly indicated as drawn from information found in Book 358, Page 567, and that the ratio of precision as determined is 1:10000 and that it was recorded in accordance with G.S. 47-30 as amended. Witness my hand and official registration number and seal this 20th day of December, A.D. 2001.



*Michael R. Bennett*  
MICHAEL R. BENNETT  
1-1514

I, MICHAEL S. JARROVICH, HEREBY CERTIFY THAT THIS PLAN WAS DRAWN UNDER THE SUPERVISION AND DIRECT OBSERVATION RECORDED IN BOOK 358, PAGE 567, AND THAT THE BOUNDARIES AND SURVEYS ARE CLEARLY INDICATED AS DRAWN FROM INFORMATION FOUND IN BOOK 358, PAGE 567, AND THAT THE RATIO OF PRECISION AS DETERMINED IS 1:10000 AND THAT IT WAS RECORDED IN ACCORDANCE WITH G.S. 47-30 AS AMENDED. WITNESS MY HAND AND OFFICIAL REGISTRATION NUMBER AND SEAL THIS 20TH DAY OF DECEMBER, A.D. 2001.


STATE OF NORTH CAROLINA

COUNTY OF HARNETT  
I, *Michael S. Jarrovich*, REVIEW OFFICER OF THE REGISTER OF DEEDS, HARNETT COUNTY, CERTIFY THAT THE MAP OR PLAT TO WHICH THIS CERTIFICATION IS REFERRED MEETS ALL STATUTORY REQUIREMENTS FOR RECORDING.

12-02 *Michael S. Jarrovich*  
DATE: REVIEW OFFICER

NORTH CAROLINA HARNETT COUNTY  
This Map/Plat was presented for registration and recorded in this office on Map Number 2001-2002-9  
DATE: 12/20/01  
BY: *Shirley J. Jarmore*  
REGISTERED CLERK OF DEEDS  
BY: *Shirley J. Jarmore*  
REGISTERED CLERK OF DEEDS

- LEGEND  
LINES NOT SURVEYED  
LINES SURVEYED  
EP-----EXISTING IRON PIPE  
EWM-----EXISTING CONCRETE MONUMENT  
NIP-----NEW IRON PIPE  
PWN-----P.W. IRON SET  
ELS-----EXISTING LIGHTWOOD STAKE  
N/E-----NEW OR FORMERLY  
N/W-----NORTH OF WAY  
C/L-----CENTERLINE  
N/S-----NEW IRON STAKE  
E/S/E/S-----EXISTING IRON STAKE  
E/P/E/S-----EXISTING CENTERLINE  
CP-----CALCULATED POINT



DEPARTMENT OF TRANSPORTATION  
DIVISION OF HIGHWAYS  
NO APPROVAL NECESSARY  
*R.R. Stone / R.A.*  
REGISTERED ENGINEER  
12-27-01

CONTINUUM CARE CORPORATION  
DB 1187.FO 272

14.42 AC. TOTAL  
- 0.40 AC. R/W  
14.02 AC. NET

16.08 AC. TOTAL

- MINIMUM BUILDING SET BACKS  
FRONT YARD --- 35'  
REAR YARD --- 25'  
SIDE YARD --- 10'  
CORNER LOT SIDE YARD --- 20'  
MAXIMUM HEIGHT --- 35'

NOTE: TRACT-1 TO RETAIN RIGHTS OF ACCESS & EGRESS ALONG THE EXISTING DRAINAGE EASEMENT ACROSS TRACT-2

DEED REFERENCE: DEED BK 358, PAGE 567  
DEED BK 818, PAGE 382

MAP REFERENCE: TWO UNRECORDED MAPS ENTITLED, SURVEY FOR JOSEPH A. BOONE AND WIFE JANET M. BOONE BY RAGSDALE CONSULTANTS, P.A. DATED 11-04-86.

SURVEY FOR:  
**JOHN D. MASON & MILDRED W. MASON**

TOWNSHIP	UPPER LITTLE RIVER	COUNTY	HARNETT
STATE	NORTH CAROLINA	DATE	DEC. 20, 2001
ZONE	RA-30	TAX PARCEL ID#	13-0640-0055 & 13-0630-0184

**BENNETT SURVEYS, INC.**  
400 CLARK HWY., L.L. HAZEN, N.C. 27046  
(301) 895-5757

60	0	120	SURVEYED BY: JSM	FIELD BOOK DC # 1
SCALE: 1" = 120'	DRAWN BY: RVM	CHECKED BY: CLC/BJE	DATE: 12/20/01	DRAWING NO. 01268

Map 2001-9

# OPERATIONS PERMIT

Attempt to  
Repair

Name: (owner) John Mason  New Installation  Septic Tank  
 Property Location: SR# Old 421  Repairs  Nitrification Line  
 Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: L. Shrage Registration # \_\_\_\_\_


Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community Old well filled in  
 Distance From Well: 50m ft. Attempt to Repair

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1200 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface No. of exact length width of depth of  
 Drainage Field ditches 1 of each ditch 200 ft. ditches 3 ft. ditches 18-24 in.  
 French Drain: \_\_\_\_\_ Linear feet

Date: 7-28-96  
 Inspected by: GWANS  
 Environmental Health Specialist

PERMIT NO. 14529





# IMPROVEMENT PERMIT

*Attempt to Repair*

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) John Mason

New Installation  Septic Tank

Property Location: SR# Old 421

Repairs

Nitrification Line

1934 Old W 421

Subdivision \_\_\_\_\_

Lot # \_\_\_\_\_

Tax ID # \_\_\_\_\_

Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3

Lot Size: 14.62 AC

Basement with Plumbing:

Garage:

*Attempt to Repair*

Water Supply:  Well  Public

Community

Distance From Well: 50m ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional

Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons

Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: \_\_\_\_\_ Linear feet

Date: 7-20-98


This permit is subject to revocation if site plans or intended use change.

Signed: [Signature]

Environmental Health Specialist


*MUST meet onsite Before installing 18-24" Ditch - Depth Follow contours MAINTAIN All Required set Backs*

*Replace old Tank*



*Do not DRIVE OR PARK ON DRAIN LINES*

*Grass area Do not Farm OR Garden OVER SEPTIC DRAIN LINES*



18-24 200 odd  
 1/11 0 odd  
 flock zone  
 door

0-18 GALS  
 18-48 5825cc