



November 16, 2006

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

Jack Dziadul
Prudential Sanford Real Estate
304 North Horner Blvd.
Sanford, NC 27330

ph: 910-893-7550
fax: 910-893-9429

Harnett County Land Use Application Existing Tank - #06-5-16049

Dear Mr. Dziadul,


The Harnett County Department of Public Health, Environmental Health Division on November 14, 2006 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a mortgage inspection, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

Applicant applied for a 4 bedroom inspection (3 bedrooms and converting bonus room to 4th bedroom) Septic system is designed for 3 bedrooms. You have the option of adding additional line to system to accommodate 4 bedrooms. You will need to apply to Central Permitting for an expansion of existing system. The fee is \$250.00 for a soil evaluation. You will only be required to pay the difference since \$100.00 was previously paid for the existing tank should you choose to go with 4th bedroom.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,


Joe West, R. S.

Environmental Health Specialist
Harnett County Department of Public Health

JW/sgs

Cc: Central Permitting