



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

August 13, 2008

Jeff Pope
2568 Old Buies Creek Rd
Angier, NC 27501

RE: Existing Septic System Inspection HTE # 08-5-20622

Dear Mr. Pope,

On August 12, 2008, an attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on the existing septic tank and break seal
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

James E. Manhart, III, R.S.
Environmental Health Specialist
Harnett County Department of Public Health
Environmental Health

JEM/sgs
Copy - Central Permitting