RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2179

1. WELL CONTRACTOR:

Roger W. Jackson
Well Contractor (Individual) Name

Jackson Well Company
Well Contractor Company Name

STREET ADDRESS 5660 McDougald Road
Lillington, North Carolina 27546
City or Town State Zip Code

(910) 893-2372
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) 10-5-24925

STATE WELL PERMIT#(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply ☑

DATE DRILLED 8-25-10

TIME COMPLETED 2:00 AM☐ PM☑

3. WELL LOCATION:

CITY: Coats COUNTY Harnett

985 McLamb Rd Coats NC. 27521
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☑Slope ☐Valley ☐Flat ☐Ridge ☐ Other Elev. 227
(check appropriate box)

LATITUDE 35° 24.074
LONGITUDE 78° 42.319

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☑GPS ☐Topographic map

(location of well must be shown on a USGS topo map and *attached to this form if not using GPS*)

4. WELL OWNER

OWNER'S NAME Randall Mac Gregory

STREET ADDRESS 1350 Fleming Rd

Coats NC 27521
City or Town State Zip Code

(919) 303-018
Area code- Phone number

5. WELL DETAILS:

a. TOTAL DEPTH: 240

b. DOES WELL REPLACE EXISTING WELL? YES☐ NO☑

c. WATER LEVEL Below Top of Casing: 22 FT.
(Use "+" If Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. YIELD (gpm): 100+ METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 16oz

g. WATER ZONES (depth):

From	To	From	To
220	221		
230	231		

h. CASING:

From	To	Depth	Diameter	Thickness/ Weight	Material
0	80	Ft.	6"	SR21	PVC
		Ft.			
		Ft.			

7. GROUT:

From	To	Depth	Material	Method
0	25	Ft.	Sand Cement	Pouring
		Ft.		
		Ft.		

8. SCREEN:

From	To	Depth	Diameter	Slot Size	Material
		Ft.	in.	in.	
		Ft.	in.	in.	
		Ft.	in.	in.	

9. SAND/GRAVEL PACK:

From	To	Depth	Size	Material
		Ft.		
		Ft.		
		Ft.		

10. DRILLING LOG

From	To	Formation Description
0	1	Top Soil
1	69	Clay
69	240	Slate

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Roger W. Jackson 8-28-10
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Roger W. Jackson
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center – Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05